



Housing Initiatives of New England Corp.
264 US Route 1
Building 300 Suite 2A
Scarborough, Maine 04074
Attn: Bill Walker

RE: Bagdad Woods New Addition Durham, NH

Dear Bill,

Please be advised that Superior Fire Protection has conducted a Hydraulic calculation to verify if city supply is adequate for flow and pressure at the above mentioned property. Superior Fire Protection has determined the water supply meets and exceeds the demands of the fire sprinkler system and domestic system which require (300 gallons per minute @ 45 PSI) available from town water supply.

Respectfully,

Eddy S. Caron

Eddy S. Caron
President
Superior Fire Protection