

**From:** Mike Sievert [<mailto:mikesievert@mjs-engineering.com>]

**Sent:** Tuesday, February 16, 2021 1:27 PM

**To:** Michael Behrendt

**Subject:** Re: Main Street #19 - revised plans

Hi Michael,

For you and the planning board. The plan changes are as follows:

C101 - No changes to this sheet. However, the two lights that are shown in the southerly corners are not there.

C102 - The underground detention system has been enlarged. Chambers have been added to the northerly row. The outlet protection at the culvert through the wall has been increased.

C103 - No change

L-100 - No changes

Lighting plan - No change

C501 - No change

C502 - No change

C503 - The entry driveway cross section was updated to reflect the change

C504 - the detail for the river stone mulched lined ditch was updated

C505 - This plan changed to reflect the design changes to the stormwater system. larger bed and some changes to the inverts of pipes

1

those are all the changes. It was mostly to the drainage system design. I can review and clarify at the meeting on Wednesday

Mike

On Feb 12, 2021, at 12:37 PM, Michael Behrendt <[mbehrendt@ci.durham.nh.us](mailto:mbehrendt@ci.durham.nh.us)> wrote:

Mike,

What specifically changed on the attached plans? Thanks.

**Michael Behrendt**

Durham Town Planner

Town of Durham

8 Newmarket Road

Durham, NH 03824

(603) 868-8064

[www.ci.durham.nh.us](http://www.ci.durham.nh.us)

<Revised plans 2-2-21.pdf>