

PHASEII

Stone Quarry Drive Durham, New Hampshire

Assessor's Parcel 209, Lot 33
ISSUED FOR REVIEW

Plan Issue Date:

October 8, 2025

Owner/Applicant: RIVERWOODS DURHAM

14 STONE QUARRY DRIVE DURHAM, NH 03824

Civil Engineer:



Surveyor:



Wetland Scientist:
MICHAEL CUOMO, CWS
6 YORK POND ROAD

YORK, ME 03909

Lighting Consultant:



Architect:




Landscape Architect:



Traffic Engineer:







WILDLIFE PROTECTION NOTES


1. SEE NOTES AND WILDLIFE FLYERS ON SHEET C-21.


Sheet No.:	Rev.	Date
No.: S-1 S-2 S-4 S-6 S-7 C-1 C-3 C-4 C-5 C-6.2 C-7.1 C-7.2 C-8.1 C-9.2 C-10.1 C-12 C-13 C-14 C-15 C-15 C-16 C-17 C-18 C-19 C-20 L-1 L-2 A500	Rev. 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Date 06/03/25 06/03/25 06/03/25 06/03/25 06/03/25 06/03/25 06/03/25 06/03/25 06/03/25 10/08/25
A502 A503	1 O	09/18/25 06/05/25
	No:: S-1 S-2 S-4 S-6 S-7 C-3 C-4 C-6.1 C-7.2 C-7.2 C-8.1 C-9.2 C-11 C-12 C-13 C-14 C-15 C-16 C-17 C-18 C-17 C-19 C-20 C-21 L-2 A501 A502	No.: Rev. S-1


Permit Summary	Submitted	Received
Durham Zoning Approval	06/17/25	07/08/25
Durham Site Plan Approval	07/23/25	<u> </u>
NHDES Alteration of Terrain	To be Submitted	_
NHDES Sewer Connection Permit	To be Submitted	_
NHDOT Driveway Permit	06/27/25	_
EPA Notice of Intent	By Contractor 14 days	prior to construction











SURVEYOR'S CERTIFICATION

"I HEREBY CERTIFY THAT THIS SURVEY AND PLAT WERE PREPARED BY ME OR THOSE UNDER MY DIRECT SUPERVISION AND IS THE RESULT OF AN ACTUAL FIELD SURVEY MADE ON THE GROUND AND HAS AN ERROR OF CLOSURE OF GREATER ACCURACY THAN ONE PART IN FIFTEEN THOUSAND (1:15,000)."


LICENSED LAND SURVEYOR

SURVEYOR:

101 SHATTUCK WAY, SUITE 8, NEWINGTON, N.H., 03801—7876 603—436—3557 JOB NO: 23-2036

ENGINEER:

6/10/25 DATE



133 Court Street Portsmouth, NH 03801 (603) 433-2335 www.altus-eng.com

ISSUED FOR:

SUBMISSION

ISSUE DATE:

1/15/24

DATE

<u>REVISIONS</u> NO. DESCRIPTION

PUBLIC WORKS

ADD DETAIL AND BJM 6/3/25 TOPO BY THE

BY

RMF DRAWN BY:_ APPROVED BY: __ DRAWING FILE: 23-2036_EXCON

 $11" \times 17" - 1" = 60"$

APPLICANT:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

PROJECT:

RIVERWOODS DURHAM TAX MAP 209 LOT 33 STONE QUARRY DRIVE & DOVER ROAD (NH RT 108) DURHAM, NH


TITLE:


120 FEET


EXISTING CONDITIONS PLAN


SHEET NUMBER:

S-5














1. DESIGN INTENT - THIS PLAN SET IS INTENDED TO DEPICT THE DEVELOPMENT OF THE SITE FOR AN EXPANSION OF THE EXISTING RIVERWOODS CONTINUING CARE RETIREMENT COMMUNITY TO INCLUDE NEW INDEPENDENT LIVING UNITS, A COMMUNITY CENTER, A MAINTENANCE GARAGE TOGETHER WITH

- 2. APPROXIMATE LOT AREA (AFTER LOT LINE ADJUSTMENT): 985,948 S.F. (±22.63 AC.)
- 3. REFERENCE DEED: STRAFFORD COUNTY REGISTRY OF DEED BOOK 4465 PAGE 0988

40,000 S.F. (80,000 MULTI-UNIT OR NON-RES.) 1 UNIT/4,200 S.F. MIN. STREET FRONTAGE: 200' (ARTERIAL), 100' (COLLECTOR), 50' (MINOR) 100' +2' PER 1' OF BLDG. HEIGHT OVER 25' (ARTERIAL)

> 50' (75' BY SPECIAL EXCEPTION) 75' (POORLY DRAINED, NATURAL WETLANDS >3,000 S.F.) 100' (VERNAL POOL)

REAR PARKING SETBACK: SAME AS REAR BUILDING SETBACK FRONT LANDSCAPE STRIP: 50' (ON ROUTE 108 ONLY) DENSITY (RESIDENTIAL): 4,200 S.F. NON-ISOLATED UPLAND/RESIDENTIAL UNIT 1 BEDROOM/STUDIO SENIOR = 0.33 RESIDENTIAL UNITS 2-3 BEDROOM SENIOR = 0.50 RESIDENTIAL UNITS 4 BEDROOM SENIOR = 1.00 RESIDENTIAL UNITS

708,212 S.F. 13.013 S.F 3,423 S.F TOTAL 724,648 S.F. UNSUITABLE LAND

985,948 S.F LOT AREA - 724,648 S.F. UNSUITABLE LAND = 261,300 S.F. USEABLE LAND 261,300 S.F. / 4,200 S.F. = 62 RESIDENTIAL (NON-SENIOR) UNITS PERMITTED 62 RES. UNITS / 0.33 = 187 1 BED/STUDIO SENIOR RES. UNITS PERMITTED 62 RES. UNITS / 0.50 = 124 2 BED SENIOR RES. UNITS PERMITTED

5. PARKING REQUIREMENTS (PER DURHAM REGULATIONS):

SENIOR HOUSING UNITS: 55 UNITS x 1 = 55 SPACES REQUIRED STAFF AT MAX. SHIFT: 1 STAFF x 17 = 17 SPACES REQUIRED (MAINTENANCE) TOTAL PARKING REQUIRED = 72 SPACES TOTAL PARKING PROVIDED = 152 SPACES (56 GARAGE, 96 SURFACE)


= +80 SPACES *FOR COMPARISON, DURHAM REGULATIONS REQUIRE 2 SPACES/UNIT FOR

PARKING DEMAND (PER APPLICANT PROJECTIONS): SENIOR HOUSING: 55 UNITS x 2 SPACES/UNIT = 110 SPACES = 20 SPACES MAINTENANCE GARAGE: 17 SPACES = 17 SPACES = 147 SPACES = 152 SPACES = +5 SPACES

- 6. OVERALL CONTIGUOUS AREA OF DISTURBANCE OVER 100,000 S.F., NHDES ALTERATION OF TERRAIN
- AREA OF DISTURBANCE OVER 43,560 SF, COVERAGE UNDER EPA NPDES PHASE II CONSTRUCTION GENERAL PERMIT REQUIRED (NOIS TO BE PREPARED AND SUBMITTED BY CONTRACTOR, SWPPP AND INSPECTIONS TO BE PREPARED AND PERFORMED BY CONTRACTOR).
- 8. NHDES SEWER DISCHARGE PERMIT REQUIRED.
- 9. NHDOT DRIVEWAY PERMIT REQUIRED.
- 10. TOWN OF DURHAM SIGN PERMIT REQUIRED FOR ALL BUSINESS SIGNS, IF ANY.
- 11. CONDITIONAL USE PERMIT UNDER ZONING SECTION 175.61 REQUIRED FOR SITE DEVELOPMENT IN THE WETLANDS CONSERVATION OVERLAY DISTRICT.
- 12. SITE IS NOT IN A SPECIAL FLOOD HAZARD ZONE PER FIRM PANEL #33017C0318E PANEL 318 OF
- 13. ALL BONDS AND FEES SHALL BE PAID/POSTED PRIOR TO INITIATING CONSTRUCTION.
- 14. ALL CONSTRUCTION SHALL CONFORM WITH THE STATE OF NEW HAMPSHIRE DEPARTMENT OF TRANSPORTATION (NHDOT) "STANDARD SPECIFICATIONS FOR ROAD AND BRIDGE CONSTRUCTION" AND WITH THE REGULATIONS AND STANDARD SPECIFICATIONS OF THE TOWN OF DURHAM, LATEST
- 15. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROPER LOCATION, INSTALLATION AND
- 16. THE APPLICANT RESERVES THE RIGHT TO INSTALL ADDITIONAL WAYFINDING SIGNS NOT SHOWN ON THIS PLAN PROVIDED THAT THEY ARE IN COMPLIANCE WITH ALL APPLICABLE LOCAL REGULATIONS.
- 17. PAVEMENT MARKINGS AND SIGNS SHALL CONFORM TO THE REQUIREMENTS OF THE "MANUAL ON UNIFORM TRAFFIC DEVICES," "STANDARD ALPHABETS FOR HIGHWAY SIGNS AND PAVEMENT
- 18. PAVEMENT MARKINGS SHALL BE CONSTRUCTED USING WHITE, YELLOW OR BLUE TRAFFIC PAINT (WHERE SPECIFIED) MEETING THE REQUIREMENTS OF AASHTO M248, TYPE F OR EQUAL. PAINTED ISLANDS AND LOADING ZONES SHALL BE 4"-WIDE DIAGONAL WHITE LINES 3'-0" O.C. BORDERED BY 4"-WIDE WHITE LINES. PARKING STALLS SHALL BE SEPARATED BY 4"-WIDE WHITE LINES. SEE
- 19. ALL EXISTING STRIPING DISTURBED BY THE WORK SHALL BE REPAINTED PRIOR TO THE CONCLUSION

SWL: SINGLE WHITE LINE (4" SOLID LINE) DYL: DOUBLE YELLOW LINE (2 x 4" SOLID LINES SEPARATED BY 4")

- 21. BOLLARDS SHALL BE LOCATED AT ALL BUILDING CORNERS IN PAVED AREAS AND AT EACH SIDE OF ALL OVERHEAD GARAGE DOORS. COORDINATE FINAL LOCATIONS WITH ARCHITECTURAL PLANS.
- 22. CLEAN AND COAT VERTICAL FACE OF EXISTING PAVEMENT AT SAWCUT LINES WITH RS-1
- 23. UNLESS OTHERWISE NOTED, ALL NEW CURBING SHALL BE SLOPED GRANITE ("SGC") OR VERTICAL
- 24. ALL CURB RAMPS AND SIDEWALKS AT CROSSWALKS SHALL BE EQUIPPED WITH ADA-COMPLIANT
- 25. ALL NEW SIDEWALKS SHOWN IN THIS PLAN SHALL BE MAINTAINED BY THE APPLICANT OR ASSIGNS
- 26. SNOW SHALL BE STORED AT THE EDGE OF PAVEMENT AND IN AREAS SHOWN HEREON AS
- 27. BUILDING AREA AND DIMENSIONS SHOWN ARE BASED ON MEASUREMENTS TO THE EXTERIOR FACE. ACTUAL DIMENSIONS TO FOUNDATION AND INTERIOR SPACE WILL DIFFER. THE CONTRACTOR SHALL VERIFY ALL BUILDING DIMENSIONS WITH THE ARCHITECTURAL AND STRUCTURAL PLANS PRIOR TO CONSTRUCTION AND SHALL BE RESPONSIBLE FOR ALL NECESSARY COORDINATION BETWEEN CIVIL AND ARCHITECTURAL PLANS TO ENSURE THE DESIGN INTENT IS MET. ALL DISCREPANCIES SHALL
- 28. THIS SITE PLAN IS DESIGNED IN COMPLIANCE WITH ALL APPLICABLE ACCESSIBILITY REGULATIONS. THE PROPOSED BUILDING IS DESIGNED IN COMPLIANCE WITH ALL APPLICABLE ACCESSIBILITY REGULATIONS INCLUDING NH RSA 155-A:5-a&b, THE IBC AND ANSI 117.1.
- 29. AT THE CONCLUSION OF THE PROJECT, THE CONTRACTOR SHALL PREPARE AN AS-BUILT SITE AND UTILITY PLAN STAMPED BY A NH LICENSED LAND SURVEYOR (LLS) & PROVIDE DIGITAL COPIES IN
- 30. STREET ADDRESSES SHALL BE ASSIGNED BY THE DURHAM FIRE DEPARTMENT PRIOR TO THE ISSUANCE OF A CERTIFICATE OF OCCUPANCY. MAIL SHALL BE TO A CENTRAL MAIL ROOM.




Portsmouth, NH 03801

www.altus-eng.com

133 Court Street

(603) 433-2335



NOT FOR CONSTRUCTION

REVIEW

ISSUED FOR:

ISSUE DATE:

OCTOBER 8, 2025

REVISIONS NO. DESCRIPTION O REVIEW EBS 06/23/

REVISED PER COMMENTS EBS 10/08/2

DRAWING FILE: ____

24" x 36" - 1" = 40' $11" \times 17" - 1" = NTS$

5440-SITE.dwa

OWNER:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824


<u>APPLICANT:</u>


RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824


RIVERWOODS DURHAM PHASE II


TAX MAP 209 LOT 33 STONE QUARRY DRIVE & DOVER ROAD (NH 108) DURHAM, NH


SITE PLAN

























GRAPHIC SCALE #6 7+19.68 = 55.20 50.05 (10") 49.95 (10") (IN FEET) 1 inch = 30 feet Horiz. #8 (PU 10+95. 53.00 48.46 (1 inch = 3 feet Vert. SMH STA. RIM= IN: OUT: - 2x6" SDR 21 L=10' S=0.02'/' EXISTING GRADE FINISH GRADE - PROPOSED PROPOSED — ELECTRIC AND COMMUNICATIONS GAS SERVICE ENCASE SEWER LINE IN 6" — OF CONCRETE TO 10' ON DUCT BANK EACH SIDE OF WATER LINE PROPOSED GAS -SERVICE REDUCER EXISTING GRADE (TYPx2) 6" INV.: 51.28 10" SDR 35 L=±278' S=0.0028'/ PROPOSED 15" DRAIN LINE CAP AND WITNESS 2" FORCE MAIN STUB STA. 11+61.23 ELEV. 47.90 - PROPOSED 8" 2" RIGID INSULATION BETWEEN -10"x6" WYE AND 6" \(\triangle \) SERVICE LATERAL WATER LINE DRAIN AND SEWER (TYP) 2x2" SDR 21 S=0.005'/" (MIN.) 2" RIGID — INSULATION (TYP) PROPOSED 6" — WATER LINE EXISTING 24" -DRAIN LINE 2" SDR 21 STUB S=0.005'/" (MIN.) PROPOSED 12" — DRAIN LINES (TYPx3)

10+00

11 + 00

12+00

SCALE: 1"=30' H, 1"=3' V

9+00

7+00

PROFILE - SEWER EXTENSION

8+00

SEWER TESTING

IN: 47.32 (10" SMH #5) OUT: 47.22 (SMH #3)

L=45' S=0.0075'/'

10" SDR 35

FORCE MAINS AND PRESSURE SEWERS SHALL BE TESTED IN ACCORDANCE WITH NHDES ENV—WQ 704.09 AND SECTION 5 OF THE AWWA C600, "INSTALLATION OF CAST IRON WATER MAINS AND THEIR APPURTENANCES" STANDARD IN EFFECT WHEN THE TEST IS CONDUCTED AT A PRESSURE EQUAL TO THE GREATER OF 150 PERCENT OF THE DESIGN OPERATING TOTAL DYNAMIC HEAD OR AT LEAST 100 PSI.

SEWER SCHEDULE

SMH #5 RIM= 62.40 SMH #1 ON EXISTING MAIN IN: 49.23 (10" SMH #6) OUT: 49.13 (TO SMH #4) RIM = 55.50IN: 45.25 (10" SMH #2)
IN: ±45.15 (10" EXISTING) 10" SDR 35 OUT: ±44.74 (10" EXISTING) L=±181' S=0.01'/' SMH #2 RIM= 53.25 SMH #6 RIM= 55.20 IN: 50.05 (10" SMH #7) OUT: 49.95 (TO SMH #5) IN: 46.54 (10" SMH #3) OUT: 46.44 (TO SMH #1) 10" SDR 35` 10" SDR 35 L=±159' S=0.0075'/' L=±258' S=0.0028'/' SMH #3 RIM= 57.70 SMH #7 RIM= 55.60 IN: 46.88 (10" SMH #4) OUT: 46.78 (SMH #2) IN: 51.16 (6"x3 - BLDG & FMx2) OUT: 50.83 (TO SMH #6) 10" SDR 35 10" SDR 35 L=32' S=0.0075'/' L=±278' S=0.0028'/' SMH #4 RIM= 57.55 SMH #8 RIM= 53.00

SEWER FLOW CALCULATIONS

RESIDENTS: 110 x 59 GPD = 6,490 GPD (BASED ON DOUBLE OCCUPANCY) COMMUNITY CENTER: 52 x 25 GPD = 1,300 GPD (BASED ON NUMBER OF SEATS) COMMUNITY CENTER EMPLOYEES: 5 x 13 GPD/DAY = 65 GPD MAINTENANCE GARAGE EMPLOYEES: 17 x 10 GPD/DAY = 170 GPD TOTAL DAILY FLOW = 8,070 GPD ANNUAL FLOW = 2,945,550 GAL.

IN: 50.00 (4" VENT) IN: 48.46 (6" BLDG)

2" SDR 11 FM

OUT: 48.00 (TO SMH #7)


L= \pm 86' S=-0.005'/' MIN. (SLOPE UP TO SMH #7)

RESIDENT FLOW BASED ON PER CAPITA AVERAGE DAILY FLOW (ADF) FROM RIVERWOODS DURHAM CAMPUS BASED ON WATER USAGE. AVERAGE OF 59 GPD/RESIDENT MEASURED 12/30/22 - 01/02/25. THIS INCLUDES FLOWS FROM CAMPUS EMPLOYEES.


AVERAGE DAILY PER CAPITA FLOW FOR THE COMMUNITY CENTER, IT'S EMPLOYEES AND MAINTENANCE GARAGE EMPLOYEES WERE CALCULATED FROM METCALF & EDDY/AECOM "WASTEWATER ENGINEERING TREATMENT AND RESOURCE RECOVERY", 5TH EDITION, USING THE FOLLOWING CATEGORIES:

COMMUNITY CENTER: COUNTRY CLUB (25 GPD/SEAT)

MAINTENANCE GARAGE: INSTITUTIONS OTHER THAN HOSPITALS (10 GPD/EMPLOYEE)



133 Court Street Portsmouth, NH 03801 (603) 433-2335 www.altus-eng.com



NOT FOR CONSTRUCTION

REVIEW

ISSUED FOR:

ISSUE DATE:

OCTOBER 8, 2025

REVISIONS
NO. DESCRIPTION
BY
DATE

REVISED PER COMMENTS

BESS 10/08/2

DRAWN BY: ______EBS

APPROVED BY: _____EBS

DRAWING FILE: ____5440-SITE.dwg

SCALE:

24" x 36" - 1" = 30' 11" x 17" - 1" = NTS

OWNER:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

<u>APPLICANT:</u>

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

ROJECT:

RIVERWOODS DURHAM PHASE II


TAX MAP 209 LOT 33 STONE QUARRY DRIVE & DOVER ROAD (NH 108) DURHAM, NH


TITLE:


SEWER PLAN AND PROFILE

SHEET NUMBER:

C - 9.2







SEDIMENT AND EROSION CONTROL NOTES

PROJECT NAME AND LOCATION

RIVERWOODS DURHAM PHASE II 14 STONE QUARRY DRIVE DURHAM, NEW HAMPSHIRE TAX MAP 209, LOT 33

OWNER/APPLICANT RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

DESCRIPTION

The project consists of a new senior independent living housing development, a community center, maintenance garage and the relocation of an existing road together with associated site improvements.

LATITUDE: 43°08'25" N

LONGITUDE: 70°54'22" W

PROJECT PHASING

The project will be completed in one phase.

NAME OF RECEIVING WATER

The site drains to an unnamed wetland complex tributary to the Oyster River.

SEQUENCE OF MAJOR ACTIVITIES

- 1. Prepare SWPPP and file NOI at least two weeks prior to initiating earthwork.
- 2. Attend pre—construction meeting with Town and relevant stakeholders.
- 3. Cut trees but do not remove stumps. 4. Install temporary erosion control measures including perimeter controls, stabilized construction entrance and inlet sediment filters as noted on the plan. All temporary erosion control
- measures shall be maintained in good working condition for the duration of the project. 5. Stump, grub and strip and stockpile loam.
- 6. Relocate utilities and roadway. 7. Shape and stabilize primary stormwater ponds and swales. At the contractors discretion, stormwater ponds may be utilized as temporary sediment ponds prior to the placment of filter
- media and select materials.

8. Construct building foundation.

- 9. Rough grade site. 10. Construct drainage structures and utilities.
- 11. Fine grade site.
- 12. Install pavement subgrade
- 13. Install base course paving.
- 14. Install curbing. 15. Install landscaping
- 16. Loam (6" min) and seed all disturbed areas not paved or otherwise stabilized.

control measures and any sediment that has been trapped by these devices.

- 17. Install top course paving.
- 10. Install striping and signage 11. When all construction activity is complete and site is stabilized, remove all temporary erosion

TEMPORARY EROSION & SEDIMENT CONTROL AND STABILIZATION PRACTICES

All work shall be in accordance with state and local permits. Work shall conform to the practices described in the "New Hampshire Stormwater Manual, Volumes 1 - 3", issued December 2008, as amended. As indicated in the sequence of Major Activities, perimeter controls shall be installed prior to commencing any clearing or grading of the site. Structural controls shall be installed concurrently with the applicable activity. Once construction activity ceases permanently in an area and permanent measures are established, perimeter controls shall be removed.

During construction, runoff will be diverted around the site with stabilized channels where possible. Sheet runoff from the site shall be filtered through appropriate perimeter controls. All storm drain inlets shall be provided with inlet protection measures.

Temporary and permanent vegetation and mulching is an integral component of the erosion and sedimentation control plan. All areas shall be inspected and maintained until vegetative cover is established. These control measures are essential to erosion prevention and also reduce costly rework of graded and shaped areas.

Temporary vegetation shall be maintained in these areas until permanent seeding is applied. Additionally, erosion and sediment control measures shall be maintained until permanent vegetation is

INSTALLATION, MAINTENANCE AND INSPECTION PROCEDURES FOR TEMPORARY EROSION AND SEDIMENT CONTROL MEASURES

A. GENERAL

These are general inspection and maintenance practices that shall be used to implement the

- 1. The smallest practical portion of the site shall be denuded at one time but in no case shall
- exceed 5 acres at any one time before disturbed areas are stabilized. 2. All control measures shall be inspected at least once each week and following any storm event of 0.25 inches or greater.
- 3. All measures shall be maintained in good working order; if a repair is necessary, it will be
- initiated within 24 hours. 4. Built-up sediment shall be removed from perimeter barriers when it has reached one—third the
- height of the barrier or when "bulges" occur. 5. All diversion dikes shall be inspected and any breaches promptly repaired.
- 6. Temporary seeding and planting shall be inspected for bare spots, washouts, and unhealthy arowth.
- 7. The owner's authorized engineer shall inspect the site on a periodic basis to review compliance
- with the Plans. 8. All roadways and parking lots shall be stabilized within 72 hours of achieving final grade.
- 9. All cut and fill slopes shall be loamed and seeded within 72 hours of achieving final grade.
- 10. An area shall be considered stable if one of the following has occurred: a. Base coarse gravels have been installed in areas to be paved;
- b. A minimum of 85% vegetated growth as been established;
- c. A minimum of 3 inches of non-erosive material such as stone of riprap has been installed; d. Erosion control blankets have been properly installed.
- 9. The length of time of exposure of area disturbed during construction shall not exceed 45 days.

B. MULCHING

Mulch shall be used on highly erodible soils, on critically eroding areas, on areas where conservation of moisture will facilitate plant establishment, and where shown on the plans.

1. Timing — In order for mulch to be effective, it must be in place prior to major storm events. There are two (2) types of standards which shall be used to assure this: a. Apply mulch prior to any storm event. This is applicable when working within 100 feet of wetlands. It will be necessary to closely monitor weather predictions, usually by contacting

the National Weather Service in Concord, to have adequate warning of

significant storms. b. Required Mulching within a specified time period. The time period can range from 21 to 28 days of inactivity on a area, the length of time varying with site conditions. Professional judgment shall be used to evaluate the interaction of site conditions (soil erodibility, season of year, extent of disturbance, proximity to sensitive resources, etc.) and

the potential impact of erosion on adjacent areas to choose an appropriate time restriction.

2. Guidelines for Winter Mulch Application —

Rate per 1,000 s.f. Hav or Straw 70 to 90 lbs.

<u>Use and Comments</u> Must be dry and free from mold. May be used with plantings.

NSTALLATION, MAINTENANCE AND INSPECTION PROCEDURES FOR TEMPORARY EROSION AND SEDIMENT CONTROL MEASURES (CONTINUED)

460 to 920 lbs. Wood Chips or Used mostly with trees and shrubs. Bark Mulch Jute and Fibrous As per manufacturer Used in slope areas Matting (Erosion Specifications water courses and other Control Blanket) areas Crushed Stone Spread more than Effective in controlling

1/2" thick

2" thick (min)

* The organic matter content is between 80 and 100%, dry weight basis. * Particle size by weight is 100% passing a 6"screen and a minimum of 70 %, maximum of 85%, passing a 0.75" screen. *The organic portion needs to be fibrous and elongated *Large portions of silts, clays or fine sands are not acceptable in the mix. * Soluble salts content is less than 4.0

*The pH should fall between 5.0 and 8.0.

wind and water erosion.

mmhos/cm.

- 3. Maintenance All mulches must be inspected periodically, in particular after rainstorms, to check for rill erosion. If less than 90% of the soil surface is covered by mulch, additional mulch shall be immediately applied.
- C. PERMANENT SEEDING -

1/4" to 1-1/2" dia.

Erosion Control Mix

- 1. Bedding stones larger than $\frac{1}{2}$, trash, roots, and other debris that will interfere with seeding and future maintenance of the area should be removed. Where feasible, the soil should be tilled to a depth of 5" to prepare a seedbed and mix fertilizer into the soil.
- 2. Fertilizer lime and organic fertilizer should be applied evenly over the area prior to or at the time of seeding and incorporated into the soil. Kinds and amounts of lime and organic fertilizer should be based on an evaluation of soil tests. When a soil test is not available, the following minimum amounts should be applied:

Agricultural Limestone @ 100 lbs. per 1,000 s.f. 10-20-20 Organic Fertilizer @ 12 lbs. per 1,000 s.f.

3. Grass Seed: Provide fresh, clean, new-crop seed complying with tolerance for purity and germination established by Official Seed Analysts of North America. Provide seed mixture composed of grass species, proportions and minimum percentages of purity, germination, and maximum percentage of weed seed, as specified:

Seed Mixture (for lawns**):

Type	Purity (%)	Germination (%)	Lbs./Acre
Tall Fescue	96	85	25
Creeping Red Fescue	96	85	25
		Total	50


Seed Mixture (For slope embankments**):

Type	<u> Purity (%)</u>	Germination (%)	<u>Lbs/Acre</u>
Creeping Red Fescue (c)	96	85	40
Perennial Rye Grass (a)	98	90	35
Redtop	95	80	5
		Tota	I 80
		lota	1 80

- a. Ryegrass shall be a certified fine—textured variety such as Pennfine, Fiesta, Yorktown,
- Diplomat, or equal. b. Fescue varieties shall include — Creeping Red and/or Hard Reliant, Scaldis, Koket, or
- c. Alternate seed mixtures may be used with the approval of the engineer and landscape
- d. Hydroseed mixtures shall not contain microplastics. Dyes shall be water-soluble and
- eco-friendly. Hydroseeding shall not occur within 75' of a wetland. ** In the event that the seed mixes shown here conflict with the project landscape plans, the landscape plans shall govern.
- 4. Sodding sodding is done where it is desirable to rapidly establish cover on a disturbed area. Sodding an area may be substituted for permanent seeding procedures anywhere on site. Bed preparation, fertilizing, and placement of sod shall be performed according to the S.C.S. Handbook. Sodding is recommended for steep sloped areas, areas immediately adjacent to sensitive water courses, easily erodible soils (fine sand/silt), etc.

WINTER CONSTRUCTION NOTES

- 1. All proposed vegetated areas which do not exhibit a minimum of 85% vegetative growth by October 15th, or which are disturbed after October 15th, shall be stabilized by seeding and installing erosion control blankets on slopes greater than 3:1, and elsewhere seeding and placing 3 to 4 tons of mulch per acre, secured with anchored netting. The installation of erosion control blankets or mulch and netting shall not occur over accumulated snow or on frozen ground and shall be completed in advance of thaw or spring melt events;
- 2. All ditches or swales which do not exhibit a minimum of 85% vegetative growth by October 15th, or which are disturbed after October 15th, shall be stabilized temporarily with stone or erosion control blankets appropriate for the design flow conditions; and
- 3. After October 15th, incomplete road or parking surfaces where work has stopped for the winter season shall be protected with a minimum of 3 inches of crushed gravel per NHDOT Item




- NOTES:

 1. SILTSOXX OR APPROVED EQUAL MAY BY USED IN PLACE OF SILT FENCE OR OTHER SEDIMENT BARRIERS. 2. ALL MATERIAL TO MEET FILTREXX SPECIFICATIONS. 3. SILTSOXX COMPOST/SOIL/ROCK/SEED FILL MATERIAL SHALL BE ADJUSTED AS NECESSARY TO MEET THE
- REQUIREMENTS OF THE SPECIFIC APPLICATION. 4. ALL SEDIMENT TRAPPED BY SILTSOXX SHALL BE DISPOSED OF PROPERLY. 5. SOCK SHALL NOT CONTAIN PLASTIC OR MULTIFILAMENT OR MONO FILAMENT POLYPROPYLENE NETTING OR

MESH WITH AN OPENING SIZE GREATER THAN 1/8". TUBULAR SEDIMENT BARRIER NOT TO SCALE

ORGANIC FILTER BERM

NOT TO SCALE



INSTALLATION AND MAINTENANCE:


INSTALLATION: REMOVE THE GRATE FROM CATCH BASIN. IF USING OPTIONAL OIL ABSORBENTS; PLACE ABSORBENT PILLOW IN UNIT. STAND GRATE ON END. MOVE THE TOP LIFTING STRAPS OUT OF THE WAY AND PLACE THE GRATE INTO CATCH BASIN INSERT SO THE GRATE IS BELOW THE TOP STRAPS AND ABOVE THE LOWER STRAPS. HOLDING THE LIFTING DEVICES, INSERT THE GRATE INTO THE INLET.

MAINTENANCE: REMOVE ALL ACCUMULATED SEDIMENT AND DEBRIS FROM VICINITY OF THE UNIT AFTER EACH STORM EVENT. AFTER EACH STORM EVENT AND AT REGULAR INTERVALS, LOOK INTO THE CATCH BASIN INSERT. IF THE CONTAINMENT AREA IS MORE THAN 1/3 FULL OF SEDIMENT, THE UNIT MUST BE EMPTIED. TO EMPTY THE UNIT, LIFT THE UNIT OUT OF THE INLET USING THE LIFTING STRAPS AND REMOVE THE GRATE. IF USING OPTIONAL ABSORBENTS; REPLACE ABSORBENT WHEN NEAR SATURATION.


UNACCEPTABLE INLET PROTECTION METHOD:

A SIMPLE SHEET OF GEOTEXTILE UNDER THE GRATE IS NOT ACCEPTABLE.

STORM DRAIN INLET PROTECTION NOT TO SCALE




- 1. ORGANIC FILTER BERMS MAY BE UTILIZED IN LIEU OF SILT FENCE OR OTHER SEDIMENT BARRIERS.
- 2. THE EROSION CONTROL MIXTURE USED IN FILTER BERMS SHALL BE A WELL-GRADED MIX OF PARTICLE SIZES THAT MAY CONTAIN ROCKS LESS THAN 4" IN DIAMETER, STUMP GRINDINGS, SHREDDED OR COMPOSTED BARK, AND/OR ACCEPTABLE MANUFACTURED PRODUCTS AND SHALL BE FREE OF REFUSE, PHYSICAL CONTAMINANTS AND MATERIAL TOXIC TO PLANT GROWTH. EROSION CONTROL MIXTURE SHALL MEET THE FOLLOWING STANDARDS:
- a) THE ORGANIC CONTENT SHALL BE 80-100% OF DRY WEIGHT.
- b) PARTICLE SIZE BY WEIGHT SHALL BE 100% PASSING A 6" SCREEN, AND 70-85% PASSING A 0.75" SCREEN.
- c) THE ORGANIC PORTION SHALL BE FIBROUS AND ELONGATED. d) LARGE PORTIONS OF SILTS, CLAYS, OR FINE SANDS SHALL NOT BE INCLUDED IN THE MIXTURE. e) SOLUBLE SALTS CONTENT SHALL BE >4.0mmhos/cm.
- f) THE pH SHALL BE BETWEEN 5.0 AND 8.0. 3. ORGANIC FILTER BERMS SHALL BE INSTALLED ALONG A RELATIVELY LEVEL CONTOUR. IT MAY BE NECESSARY TO CUT TALL GRASSES OR WOODY VEGETATION TO AVOID CREATING VOIDS AND BRIDGES THAT WOULD ENABLE FINES TO WASH UNDER THE BERM.
- 4. ON SLOPES LESS THAN 5%, OR AT THE BOTTOM OF SLOPES NO STEEPER THAN 3:1 AND UP TO 20' LONG, THE BERM SHALL BE A MINIMUM OF 12" HIGH (AS MEASURED ON THE UPHILL SIDE) AND A MINIMUM OF 36" WIDE. ON LONGER AND/OR STEEPER SLOPES, THE BERM SHALL BE TALLER AND WIDER TO ACCOMMODATE THE POTENTIAL FOR ADDITIONAL RUNOFF (MAXIMUM HEIGHT SHALL NOT EXCEED 2').
- . FROZEN GROUND, OUTCROPS OF BEDROCK, AND VERY ROOTED FORESTED AREAS PRESENT THE MOST PRACTICAL AND EFFECTIVE LOCATIONS FOR ORGANIC FILTER BERMS. OTHER BMP'S SHOULD BE USED AT LOW POINTS OF CONCENTRATED RUNOFF, BELOW CULVERT OUTLET APRONS, AROUND CATCH BASINS, AND AT THE BOTTOM OF STEEP PERIMETER SLOPES THAT HAVE A LARGE CONTRIBUTING
- 6. SEDIMENT SHALL BE REMOVED FROM BEHIND THE FILTER BERMS WHEN IT HAS ACCUMULATED TO ONE HALF THE ORIGINAL HEIGHT OF THE BERM.
- 7. ORGANIC FILTER BERMS MAY BE LEFT IN PLACE ONCE THE SITE IS STABILIZED PROVIDED ANY SEDIMENT DEPOSITS TRAPPED BY THEM ARE REMOVED AND DISPOSED OF PROPERLY.
- 8. FILTER BERMS ARE PROHIBITED AT THE BASE OF SLOPES STEEPER THAN 8% OR WHERE THERE IS FLOWING WATER WITHOUT THE SUPPORT OF ADDITIONAL MEASURES SUCH AS SILTFENCE.



- 1. THE AREA UNDER THE EMBANKMENT SHALL BE CLEARED, GRUBBED, AND STRIPPED OF ALL VEGETATION, ROOTS, AND DEBRIS.
- 2. THE FILL MATERIAL FOR THE EMBANKMENT SHALL BE FREE OF ROOTS, WOODY VEGETATION, STONES OVER 6" SIZE, ORGANIC MATERIAL, OR OTHER OBJECTIONABLE MATERIALS. THE FILL SHALL BE COMPACTED BY ROUTING CONSTRUCTION EQUIPMENT OVER IT SO THAT THE ENTIRE AREA OF THE FILL IS TRAVERSED BY AT LEAST ONE WHEEL OR TREAD TRACK OF THE EQUIPMENT.
- 3. CONSTRUCTION OPERATIONS SHALL BE CARRIED OUT IN SUCH A MANNER THAT EROSION AND WATER POLLUTION ARE MINIMIZED.
- 4. ALL CUT AND FILL SLOPES SHALL BE 2:1 (H:V) OR FLATTER.
- 5. OUTLET CREST ELEVATIONS SHALL BE AT LEAST ONE FOOT BELOW THE TOP OF THE EMBANKMENT.
- 6. OUTLET CREST IS TO BE STABILIZED WITH AMOCO #2004 GEOTEXTILE (OR APPROVED EQUAL), WHICH IS TO BE TOED INTO THE GROUND AT ITS ENDS AT LEAST SIX INCHES AND IS TO EXTEND AT LEAST ONE FOOT INTO THE TRAP AND ONE FOOT DOWNSTREAM FROM THE OUTLET EDGE FOR THE ENTIRE LENGTH OF THE CREST.
- 7. ALL DISTURBED AREAS SHALL BE VEGETATED USING THE APPROPRIATE VEGETATIVE BEST MANAGEMENT PRACTICE.
- 8. ALL TRAPS ARE TO HAVE SEDIMENT DEPOSITS REMOVED AND DISPOSED PROPERLY ONCE THEY REACH HALF THE CAPACITY OF THE TRAP.

TEMPORARY SEDIMENT TRAP

NOT TO SCALE




CONSTRUCTION SPECIFICATIONS

- 1. <u>STONE SIZE</u> 3" MINIMUM.
- 2. <u>LENGTH</u> DETAILED ON PLANS (50 FOOT MINIMUM).
- 3. <u>THICKNESS</u> SIX (6) INCHES (MINIMUM).
- 4. WIDTH FULL DRIVE WIDTH UNLESS OTHERWISE SPECIFIED.
- 5. FILTER FABRIC MIRAFI 600X OR EQUAL APPROVED BY ENGINEER. SURFACE WATER CONTROL - ALL SURFACE WATER THAT IS FLOWING TO OR DIVERTED TOWARD THE ONSTRUCTION ENTRANCE SHALL BE PIPED BENEATH THE ENTRANCE. IF PIPING IS IMPRACTICAL, A
- BERM WITH 5:1 SLOPES THAT CAN BE CROSSED BY VEHICLES MAY BE SUBSTITUTED FOR THE PIPE. MAINTENANCE - THE ENTRANCE SHALL BE MAINTAINED IN A CONDITION WHICH WILL PREVENT RACKING OR FLOWING OF SEDIMENT ONTO PUBLIC RIGHTS-OF-WAY. THIS WILL REQUIRE PERIODIC TOP DRESSING WITH ADDITIONAL STONE OR ADDITIONAL LENGTH AS CONDITIONS DEMAND AND REPAIR AND/OR CLEANOUT OF ANY MEASURES USED TO TRAP SEDIMENT. ALL SEDIMENT SPILLED,


DROPPED, WASHED OR TRACKED ONTO PUBLIC RIGHTS-OF-WAY MUST BE REMOVED IMMEDIATELY.

- 8. WHEELS SHALL BE CLEANED TO REMOVE MUD PRIOR TO ENTRANCE ONTO PUBLIC RIGHTS-OF-WAY. WHEN WASHING IS REQUIRED, IT SHALL BE DONE ON AN AREA STABILIZED WITH STONE WHICH DRAINS INTO AN APPROVED SEDIMENT TRAPPING DEVICE.
- 9. STABILIZED CONSTRUCTION EXITS SHALL BE INSTALLED AT ALL ENTRANCES TO PUBLIC RIGHTS-OF-WAY, AT LOCATIONS SHOWN ON THE PLANS, AND/OR WHERE AS DIRECTED BY THE

STABILIZED CONSTRUCTION EXIT NOT TO SCALE



Portsmouth, NH 03801 133 Court Street (603) 433-2335 www.altus-eng.com



NOT FOR CONSTRUCTION

REVIEW

SSUED FOR:

ISSUE DATE: **OCTOBER 8, 2025**

<u>REVISIONS</u> NO. DESCRIPTION BY DATE O REVIEW EBS 06/23/ REVISED PER COMMENTS EBS 10/08/2

DRAWN BY:. APPROVED BY: ____ 5440-SITE.dwa

DRAWING FILE: ____

SCALE:

24" x 36" - 1" = NTS $11" \times 17" - 1" = NTS$

OWNER:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

<u>APPLICANT:</u>


RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824


RIVERWOODS DURHAM PHASE II

TAX MAP 209 LOT 33 STONE QUARRY DRIVE & DOVER ROAD (NH 108) DURHAM, NH

TITLE:

DETAIL SHEET






NOTES

- CONTAINMENT MUST BE STRUCTURALLY SOUND AND LEAK FREE AND CONTAIN ALL LIQUID WASTES.
 CONTAINMENT DEVICES MUST BE OF SUFFICIENT QUANTITY OR VOLUME TO COMPLETELY CONTAIN THE
- LIQUID WASTES GENERATED.
- 3. WASHOUT MUST BE CLEANED OR NEW FACILITIES CONSTRUCTED AND READY TO USE ONCE WASHOUT IS 75% FULL.
- 4. WASHOUT AREA(S) SHALL BE INSTALLED IN A LOCATION EASILY ACCESSIBLE BY CONCRETE TRUCKS.5. ONE OR MORE AREAS MAY BE INSTALLED ON THE CONSTRUCTION SITE AND MAY BE RELOCATED AS
- CONSTRUCTION PROGRESSES.
- 6. AT LEAST WEEKLY REMOVE ACCUMULATION OF SAND AND AGGREGATE AND DISPOSE OF PROPERLY.

CONCRETE WASHOUT


NOT TO SCALE




<u>NOTES</u>

- 1. PREPARE SOIL BEFORE INSTALLING BLANKETS, INCLUDING ANY NECESSARY APPLICATION OF LIME, FERTILIZER. AND SEED.
- 2. BEGIN AT THE TOP OF THE SLOPE BY ANCHORING THE BLANKET IN A 6" DEEP BY 6" WIDE TRENCH WITH APPROXIMATELY 12" OF BLANKET EXTENDED BEYOND THE UP-SLOPE PORTION OF THE TRENCH. ANCHOR THE BLANKET WITH A ROW OF STAPLES/STAKES APPROXIMATELY 12" APART IN THE BOTTOM OF THE TRENCH. BACKFILL AND COMPACT THE TRENCH AFTER STAPLING. APPLY SEED TO COMPACTED SOIL AND FOLD REMAINING 12" PORTION OF BLANKET BACK OVER SEED AND COMPACTED SOIL. SECURE BLANKET OVER COMPACTED SOIL WITH A ROW OF STAPLES/STAKES SPACED APPROXIMATELY 12" APART ACROSS THE WIDTH OF THE BLANKET.
- 3. ROLL THE BLANKETS (A) DOWN OR (B) HORIZONTALLY ACROSS THE SLOPE. BLANKETS WILL UNROLL WITH APPROPRIATE SIDE AGAINST THE SOIL SURFACE. ALL BLANKETS MUST BE SECURELY FASTENED TO SOIL SURFACE BY PLACING STAPLES/STAKES IN APPROPRIATE LOCATIONS AS SHOWN IN THE STAPLE PATTERN GUIDE.
- 4. THE EDGES OF PARALLEL BLANKETS MUST BE STAPLED WITH APPROXIMATELY 2"-5" OVERLAP DEPENDING ON BLANKET TYPE. TO ENSURE PROPER SEAM ALIGNMENT, PLACE THE EDGE OF THE OVERLAPPING BLANKET (BLANKET BEING INSTALLED ON TOP) EVEN WITH THE COLORED SEAM STITCH ON THE PREVIOUSLY INSTALLED BLANKET.
- 5. CONSECUTIVE BLANKETS SPLICED DOWN THE SLOPE MUST BE PLACED END OVER END (SHINGLE STYLE) WITH AN APPROXIMATE 3" OVERLAP. STAPLE THROUGH OVERLAPPED AREA, APPROXIMATELY 12" APART ACROSS ENTIRE BLANKET WIDTH. NOTE: IN LOOSE SOIL CONDITIONS, THE USE OF STAPLE OR STAKE LENGTHS GREATER THAN 6" MAY BE NECESSARY TO PROPERLY SECURE THE BLANKETS.

EROSION CONTROL BLANKET - SLOPE NOT TO SCALE




WOOD BEAM GUARDRAIL



<u>NOTES</u>


- 1. PREPARE SOIL BEFORE INSTALLING BLANKETS, INCLUDING ANY NECESSARY APPLICATION OF LIME, FERTILIZER, AND SEED.
- 2. BEGIN AT THE TOP OF THE CHANNEL BY ANCHORING THE BLANKET IN A 6" DEEP BY 6" WIDE TRENCH WITH APPROXIMATELY 12" OF BLANKET EXTENDED BEYOND THE UP-SLOPE PORTION OF THE TRENCH. ANCHOR THE BLANKET WITH A ROW OF STAPLES/STAKES APPROXIMATELY 12" APART IN THE BOTTOM OF THE TRENCH. BACKFILL AND COMPACT THE TRENCH AFTER STAPLING. APPLY SEED TO COMPACTED SOIL AND FOLD REMAINING 12" PORTION OF BLANKET BACK OVER SEED AND COMPACTED SOIL. SECURE BLANKET OVER COMPACTED SOIL WITH A ROW OF STAPLES/STAKES SPACED APPROXIMATELY 12" APART ACROSS THE WIDTH OF THE BLANKET.
- 3. ROLL CENTER BLANKET IN DIRECTION OF WATER FLOW IN BOTTOM OF CHANNEL. BLANKETS WILL UNROLL WITH APPROPRIATE SIDE AGAINST THE SOIL SURFACE. ALL BLANKETS MUST BE SECURELY FASTENED TO SOIL SURFACE BY PLACING STAPLES/STAKES IN APPROPRIATE LOCATIONS AS SHOWN IN THE STAPLE PATTERN GUIDE.
- 10 SOIL SURFACE BY PLACING STAPLES/STAKES IN APPROPRIATE LOCATIONS AS SHOWN IN THE STAPLE PATTERN GUIDE.

 4. PLACE CONSECUTIVE BLANKETS END OVER END (SHINGLE STYLE) WITH A 4"-6" OVERLAP. USE A DOUBLE ROW OF STAPLES STAGGERED 4" APART AND 4" ON CENTER TO SECURE BLANKETS.
- 5. FULL LENGTH EDGE OF BLANKETS AT TOP OF SIDE SLOPES MUST BE ANCHORED WITH A ROW OF STAPLES/STAKES APPROXIMATELY 12" APART IN A 6" DEEP BY 6" WIDE TRENCH. BACKFILL AND COMPACT THE TRENCH AFTER STAPLING.
- 6. ADJACENT BLANKETS MUST BE OVERLAPPED APPROXIMATELY 2"-5" (DEPENDING ON BLANKET TYPE) AND STAPLED. TO INSURE PROPER SEAM ALIGNMENT, PLACE THE EDGE OF THE OVERLAPPING BLANKET (BLANKET BEING INSTALLED ON TOP) EVEN WITH THE COLORED SEAM STITCH ON THE BLANKET BEING OVERLAPPED.
- 7. IN HIGH FLOW CHANNEL APPLICATIONS, A STAPLE CHECK SLOT IS RECOMMENDED AT 30 TO 40 FOOT INTERVALS. USE A DOUBLE ROW OF STAPLES STAGGERED 4" APART AND 4" ON CENTER OVER ENTIRE WIDTH OF THE CHANNEL.
- 8. THE TERMINAL END OF THE BLANKETS MUST BE ANCHORED WITH A ROW OF STAPLES/STAKES APPROXIMATELY 12" APART IN A 6" DEEP BY 6" WIDE TRENCH. BACKFILL AND COMPACT THE TRENCH AFTER STAPLING.



CRITICAL POINTS:

A. OVERLAPS AND SEAMS
B. PROJECTED WATER LINE
C. CHANNEL BOTTOM/SIDE SLOPE VERTICES




* HORIZONTAL STAPLE SPACING SHOULD BE ALTERED IF NECESSARY TO ALLOW STAPLES TO SECURE THE CRITICAL POINTS ALONG THE CHANNEL SURFACE.

** IN LOOSE SOIL CONDITIONS THE LISE OF STAPLE OF STARLE LENGTHS

** IN LOOSE SOIL CONDITIONS, THE USE OF STAPLE OR STAKE LENGTHS GREATER THAN 6" MAY BE NECESSARY TO PROPERLY ANCHOR THE BLANKETS.

EROSION CONTROL BLANKET - SWALE NOT TO SCALE



MAINTENANCE

NOT TO SCALE

THE OUTLET PROTECTION SHOULD BE CHECKED AT LEAST ANNUALLY AND AFTER EVERY MAJOR STORM. IF THE RIPRAP HAS BEEN DISPLACED, UNDERMINED OR DAMAGED, IT SHOULD BE REPAIRED IMMEDIATELY. THE CHANNEL IMMEDIATELY BELOW THE OUTLET SHOULD BE CHECKED TO SEE THAT EROSION IS NOT OCCURRING. THE DOWNSTREAM CHANNEL SHOULD BE KEPT CLEAR OF OBSTRUCTIONS SUCH AS FALLEN TREES, DEBRIS, AND SEDIMENT THAT COULD CHANGE FLOW PATTERNS AND/OR TAILWATER DEPTHS ON THE PIPES. REPAIRS MUST BE CARRIED OUT IMMEDIATELY TO AVOID ADDITIONAL DAMAGE TO THE OUTLET PROTECTION APRON.

CONSTRUCTION SPECIFICATIONS

- 1. THE SUBGRADE FOR THE FILTER MATERIAL, GEOTEXTILE FABRIC, AND RIPRAP SHALL BE PREPARED TO THE LINES AND GRADES SHOWN ON THE PLANS.
- THE LINES AND GRADES SHOWN ON THE PLANS.


 2. THE ROCK OR GRAVEL USED FOR FILTER OR RIPRAP SHALL CONFORM TO THE SPECIFIED GRADATION.


 3. GEOTEXTILE FABRICS SHALL BE PROTECTED FROM PUNCTURE OR TEARING DURING THE PLACEMENT OF THE ROCK RIPRAP. DAMAGED AREAS IN THE FABRIC SHALL BE REPAIRED BY PLACING A PIECE
- OVERLAPS REQUIRED FOR JOINING TWO PIECES OF FABRIC SHALL BE A MINIMUM OF 12 INCHES.

 4. STONE FOR THE RIP RAP MAY BE PLACED BY EQUIPMENT AND SHALL BE CONSTRUCTED TO THE FULL LAYER THICKNESS IN ONE OPERATION AND IN SUCH A MANNER AS TO PREVENT SEGREGATION OF THE STONE SIZES.

OF FABRIC OVER THE DAMAGED AREA OR BY COMPLETE REPLACEMENT OF THE FABRIC. ALL

RIPRAP OUTLET PROTECTION NOT TO SCALE






NOTES

- 1. LEVEL SPREADERS SHALL BE CONSTRUCTED PER STORMWATER MANAGEMENT FOR MAINE, "VOLUME III BMPS TECHNICAL DESIGN MANUAL, CHAPTER 5.2.2, BUFFER WITH STONE BERMED LEVEL LIP SPREADER", LATEST EDITION.
- FOR EROSION CONTROL BLANKET STAPLE REQUIREMENTS SEE MANUFACTURER'S STANDARDS & SPECIFICATIONS FOR PROTECTIVE MATERIALS.
 AREAS BELOW LEVEL SPREADERS SHALL BE STABILIZED PRIOR TO DIRECTING RUNOFF TO THEM.

LEVEL SPREADER NOT TO SCALE



<u>NOTES</u>


- 1. CONSTRUCT PLUNGE POOL TO THE WIDTHS AND LENGTHS SHOWN ON THE PLAN.
- 2. THE SUBGRADE FOR THE GEOTEXTILE FABRIC AND RIPRAP SHALL BE PREPARED TO ACCOUNT FOR THE DEPTH OF RIPRAP.
- 3. EROSION STONE USED FOR THE PLUNGE POOL SHALL MEET THE FOLLOWING GRADATION:

 SIZE PERCENT PASSING BY WEIGHT


 18" 100

 12" 90-100
- 4. GEOTEXTILE FABRICS SHALL BE PROTECTED FROM PUNCTURE OR TEARING DURING THE PLACEMENT OF THE EROSION STONE. DAMAGED AREAS IN THE FABRIC SHALL BE REPAIRED BY PLACING A PIECE OF FABRIC OVER THE DAMAGED AREA OR BY COMPLETE REPLACEMENT OF THE FABRIC. ALL OVERLAPS REQUIRED FOR REPAIRS OR JOINING TWO PIECES OF FABRIC SHALL BE A MINIMUM OF 18"
- 5. THE EROSION STONE MAY BE PLACED BY EQUIPMENT AND SHALL BE CONSTRUCTED TO THE FULL LAYER THICKNESS IN ONE OPERATION AND IN SUCH A MANNER AS TO PREVENT SEGREGATION OF THE STONE SIZES.

PLUNGE POOL




EXTERIOR ROOF DRAIN CONNECTION NOT TO SCALE



ALTUS

133 Court Street Portsmouth, NH 03801 (603) 433-2335 www.altus-eng.com



NOT FOR CONSTRUCTION

REVIEW

ISSUED FOR:

ISSUE DATE:

JULY 23, 2025

REVISIONS
NO. DESCRIPTION
O REVIEW

IPTION BY DATE EBS 06/23/2

DRAWN BY: ______EBS

APPROVED BY: _____EBS

DRAWING FILE: ____5440-SITE.dwg

SCALE:

NOT TO SCALE

24" x 36" - 1" = NTS 11" x 17" - 1" = NTS

<u>OWNER:</u>

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

<u>APPLICANT:</u>

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

PROJECT:


RIVERWOODS DURHAM PHASE II


TAX MAP 209 LOT 33 STONE QUARRY DRIVE & DOVER ROAD (NH 108) DURHAM, NH

TTLE:

DETAIL SHEET

SHEET NUMBER:





			MATERIAL	. GRADATIONS			
3/4" ST	ONE CHOKER COURSE *	GRAV	EL FILTER COURSE **	3/8" PEA	A STONE FILTER BLANKET	3/4" STON	NE RESERVOIR COURSE **
Sieve size	% Passing by weight	Sieve size	% Passing by weight	Sieve size	% Passing by weight	Sieve size	% Passing by weight
1" 3/4" 3/8" #4 #8	100% 90 - 100% 20 - 55% 0 - 10% 0 - 5%	3/8" #4 #8	100% 70 - 85% 0 - 6%	1/2" 3/8" #4 #8 #16	100% 85 - 100% 10 - 30% 0 - 10% 0 - 5%	1" 3/4" 3/8" #4 #8	100% 90 - 100% 20 - 55% 0 - 10% 0 - 5%

BE SUBSTITUTED UPON WRITTEN

APPROVAL OF THE ENGINEER

1. DESIGN OF POROUS PAVEMENT SHALL BE IN ACCORDANCE WITH UNHSC DESIGN SPECIFICATIONS FOR POROUS ASPHALT PAVEMENT AND INFILTRATION BEDS.

STONE SIZE #67 - SECTION 703

NHDOT STANDARD SPECIFICATIONS

- 2. THE CONSTRUCTION OF THE POROUS PAVEMENT SHALL BE IN ACCORDANCE WITH THE UNHSC DESIGN SPECIFICATIONS FOR POROUS ASPHALT PAVEMENT AND INFILTRATION BEDS.
- 3. CONTRACTOR SHALL PROVIDE SUBMITTALS FOR POROUS PAVEMENT AS NOTED IN THE SPECIFICATIONS A MINIMUM OF 14-DAYS PRIOR TO COMMENCING CONSTRUCTION.
- 4. THE ENGINEER SHALL INSPECT SITE PREPARATION AND INSTALLATION OF POROUS PAVEMENT.
- 5. CONTRACTOR SHALL NOTIFY ENGINEER A MINIMUM OF 7 DAYS IN ADVANCE OF WORK SO THAT THE ENGINEER CAN OBSERVE INSTALLATION OF POROUS PAVEMENT CROSS SECTION.
- 6. CONTRACTOR TO REMOVE ANY EXISTING BURIED LAYERS OF LOAM OR UNSUITABLE MATERIAL ENCOUNTERED DURING THE EXCAVATION OF THE POROUS PAVEMENT AREA TO AT LEAST 18" BELOW THE BOTTOM OF THE POROUS PAVEMENT CROSS SECTION.

7. PROOF ROLL THE EXISTING SUBGRADE PRIOR TO SCARIFYING <u>ONLY AT AREAS REQUESTED BY THE ENGINEER.</u> SAND FILL SHALL BE ADDED IN ALL LOCATIONS WHERE THE BOTTOM OF THE RESERVOIR COURSE IS ABOVE THE EXISTING SUBGRADE.

8. POROUS PAVEMENT BASE MATERIAL AND ASPHALT SHALL NOT BE INSTALLED UNTIL ALL OTHER SITE WORK AND BUILDING CONSTRUCTION IS SUBSTANTIALLY COMPLETE AND THE SURROUNDING AREA HAS BEEN STABILIZED. THIS SHALL INCLUDE THE INSTALLATION OF LANDSCAPING.

STONE SIZE #67 - SECTION 703

NHDOT STANDARD SPECIFICATIONS

- 9. THE TOP LAYER (WEARING COURSE) SHALL BE PRE-BLENDED PG 76-28 MODIFIED WITH SBS. THE BASE COURSE SHOULD BE, AT A MINIMUM, PG 64-28 WITH 5 POUNDS OF FIBER PER TON ASPHALT MIX. IF SUFFICIENT STAGING OR USE OF THE BASE COURSE SECTION WILL BE REQUIRED PRIOR TO THE APPLICATION OF THE WEARING COURSE, THE USE OF PRE-BLENDED PG 64V-28 MODIFIED WITH
- 10. AFTER INSTALLATION, THE MIXING OR RINSING OF CONCRETE, GYPSUM, PAINT OR ANY OTHER SIMILAR ACTIVITY SHALL BE STRICTLY PROHIBITED ON ANY SECTION OF POROUS PAVEMENT OR IN ANY UPHILL CONTRIBUTING AREA.

SBS ON BOTH COURSES MAY PERMITTED AT THE DISCRETION OF THE ENGINEER.

POROUS PAVEMENT CROSS SECTION

NOT TO SCALE

Embankment Materia

% Passing sieve

90 - 100%

50 - 80%


29 – 43%

15 - 30%

100%

90 - 100%

20 - 55%



- 1. WHEN CONTRACTOR EXCAVATES BIORETENTION POND AREA TO SUBGRADE, DESIGN ENGINEER SHALL PERFORM SUBSURFACE EVALUATION PRIOR TO THE PLACEMENT OF ANY SELECT MATERIAL OR OTHER
- 2. SOIL FILTER MEDIA SHALL EITHER OPTION A OR OPTION B AT CONTRACTOR'S DISCRETION. 3. DO NOT PLACE BIORETENTION POND INTO SERVICE UNTIL ITS SIDE SLOPES AND CONTRIBUTING AREAS HAVE
- BEEN STABILIZED 4. DO NOT DISCHARGE SEDIMENT-LADEN WATERS FROM CONSTRUCTION ACTIVITIES TO THE BIORETENTION POND
- DURING ANY STAGE OF CONSTRUCTION. 5. DO NOT TRAFFIC EXPOSED SURFACES OF BIORETENTION POND WITH CONSTRUCTION EQUIPMENT. IF
- FEASIBLE, PERFORM EXCAVATION ACTIVITIES WITH EQUIPMENT POSITIONED OUTSIDE THE LIMITS OF THE 6. POND BERMS SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE STORMWATER POND BERM DETAIL.


MAINTENANCE REQUIREMENTS

- SYSTEMS SHOULD BE INSPECTED AT LEAST TWICE ANNUALLY, AND FOLLOWING ANY RAINFALL EXCEEDING 2.5 INCHES IN A 24-HOUR PERIOD, WITH MAINTENANCE OR REHABILITATION CONDUCTED AS A WARRANTED BY SUCH INSPECTION.
- PRETREATMENT MEASURES SHOULD BE INSPECTED AT LEAST TWICE ANNUALLY, AND CLEANED OF ACCUMULATED SEDIMENT AS WARRANTED BY INSPECTION, BUT NO LESS THAN ONCE ANNUALLY.
- AT LEAST ONCE ANNUALLY, SYSTEM SHOULD BE INSPECTED FOR DRAWDOWN TIME. IF BIORETENTION SYSTEM DOES NOT DRAIN WITHIN 72-HOURS FOLLOWING A RAINFALL EVENT, THEN A QUALIFIED PROFESSIONAL SHOULD ASSESS THE CONDITION OF THE FACILITY TO DETERMINE MEASURES REQUIRED TO RESTORE FILTRATION FUNCTION OR INFILTRATION FUNCTION (AS APPLICABLE), INCLUDING BUT NOT LIMITED TO REMOVAL OF ACCUMULATED SEDIMENTS OR RECONSTRUCTION OF THE FILTER MEDIA.
- VEGETATION SHOULD BE INSPECTED AT LEAST ANNUALLY, AND MAINTAINED IN HEALTHY CONDITION, INCLUDING, WEED WHACKING, REMOVAL, AND REPLACEMENT OF DEAD OR DISEASED VEGETATION, AND REMOVAL OF INVASIVE SPECIES. BERM AREAS ARE TO BE MOWED TWICE ANNUALLY.

DESIGN REFERENCES

- UNH STORMWATER CENTER
- EPA (1999A)

• NEW HAMPSHIRE STORMWATER MANAGEMENT MANUAL, VOLUME 2, DECEMBER 2008 AS AMENDED. BIORETENTION POND (BIO #'S 1, 2, 3 AND 4)




ANTI-SEEP COLLAR SHALL BE WATERPROOF AND HAVE A WATERTIGHT CONNECTION TO THE PIPE-DIAMETER OF PIPE 2' MIN. PROJECTION

ANTI-SEEP COLLARS SHALL BE CLAY, CONCRETE, PLASTIC (AGRI-DRAIN), OR EQUAL APPROVED BY THE


ANTI-SEEP COLLAR

NOT TO SCALE



- 1. THIS DETAIL IS INTENDED FOR USE WITH BIORETENTION POND UNDERDRAINS ONLY. SEE OTHER DETAILS FOR CLEANOUTS IN OTHER AREAS.
- 2. CLEANOUT LOCATIONS ARE MARKED "CO" ON STORMWATER MANAGEMENT PLANS.
- 3. CLEANOUTS MAY NOT BE SET TO FINISH GRADE WITHOUT APPROVAL FROM THE ENGINEER.

BIORETENTION U.D. CLEANOUT ("CO") NOT TO SCALE



<u>Construction Criteria</u>

- 1. Foundation Preparation —— The foundation shall be cleared of trees, logs, stumps, roots, brush, boulders, sod, and rubbish. If suitable for reuse, the topsoil and sod shall be stockpiled and spread on the completed embankment and spillways. Foundation surfaces shall be sloped no steeper than 1:1. The foundation area shall be thoroughly scarified before placement of fill material The surface shall have moisture added and/or it shall be compacted if necessary so that the first layer of fill can be bonded to the foundation.
- The cutoff trench and any other required excavations shall be dug to the lines and grades shown on the plans or as staked in the field. If they are suitable, excavated materials shall be used in the permanent fill.
- Existing stream channels in the foundation area shall be sloped no steeper than 1:1 and deepened and widened as necessary to remove all stones, gravel, sand, stumps, roots, and other objectionable material and to accommodate compaction equipment.

Foundation areas shall be kept free of standing water when fill is being placed on them.

- 2. Granular Fill Placement The material placed in the fill shall be free of sod, roots, frozen soil, stones more than 4 inches in diameter and other objectionable material.
- Selected backfill material shall be placed around structures, pipe conduits, and drainage diaphragm at about the same rate on all sides to prevent damage from unequal loading.
- The placing and spreading of fill material shall be started at the lowest point of the foundation and the fill brought up in horizontal layers of such thickness that the required compaction can be obtained. The fill shall be constructed in 8" continuous horizontal layers except where openings or sectionalized fills are required. In those cases, the slope of the bonding surfaces between the embankment in place and the embankment to be placed shall not be steeper than 3 horizontal to 1 vertical. The bonding surface shall be treated the same as that specified for the foundation so as to insure a good bond with the new fill.
- The distribution and gradation of materials shall be such that no lenses, pockets, streaks, or layers of material differ substantially in texture of gradation from the surrounding material. If it is necessary to use materials of varying texture and gradation, the more impervious material shall be placed in the center and upstream parts of the fill. If zoned fills of substantially differing materials are specified, the zones shall be placed according to the lines and grades shown on the drawings. The complete work shall conform to the lines, grades, and elevations shown on the drawings or as staked in the field.
- Moisture Control —— The moisture content of the fill material shall be adequate for obtaining the required compaction. Material that is too wet shall be dried to meet this requirement, and
- 4. Compaction —— Construction equipment shall be operated over the areas of each layer of fill to insure that the required compaction is obtained. Special equipment shall be used if needed to obtain the required compaction.
- Fill material shall be compacted to not less than 95% of AASHTO T99 Method C compaction method.

material that is too dry shall have water added and mixed until the requirement is met.

- Fill adjacent to structures, pipe conduits, and drainage diaphragm shall be compacted to a density equivalent to that of the surrounding fill by means of hand tamping or manually directed power tamper or plate vibrators. Fill adjacent to concrete structures shall not be compacted until the concrete is strong enough to support the load.
- 5. Protection —— A protective cover of vegetation shall be established on all exposed surfaces of the embankment, spillway, and borrow area in accordance with the plans. If soil or climatic conditions preclude the use of vegetation and protection is needed, non-vegetative means, such as mulches or gravel, may be used. In some places, temporary vegetation may be used until

<u>Maintenance</u>

Maintenance is necessary if detention/retention basins are to continue to function as originally designed. A local government, a designated group such as a homeowners' association, or an individual must be assigned responsibility for maintaining the structures and the basin area. A maintenance plan should be developed that outlines the maintenance operations and a schedule for carrying out the procedures.


The following should be considered in formulating a maintenance plan:

conditions permit establishment of permanent vegetation.


- 1. Embankment —— The embankment should be inspected annually to determine if rodent burrows, wet areas, or erosion of the fill is taking place.
- 2. Vegetation —— The vegetated areas of the structure should be protected from damage by fire, grazing, traffic, and dense weed growth. Lime and fertilizer should be applied as necessary as determined by soil tests. Trees and shrubs should be kept off the embankment and emergency spillway areas.
- 3. Inlets —— Pipe inlets and spillway structures should be inspected annually and after every major storm. Accumulated debris and sediment should be removed.
- 4. Outlets —— Pipe outlets should be inspected annually and after every major storm. The condition of the pipes should be noted and repairs made as necessary. If erosion is taking place, then measures should be taken to stabilize and protect the affected area.
- 5. Sediment —— Sediment should be continually checked in the basin. When sediment accumulations reach the predetermined design elevation, then the sediment should be removed and properly disposed of.
- 6. Safety Inspections —— All permanent impoundments should be inspected by a qualified professional engineer on a periodic basis. If there is potential for significant damage or loss of life downstream, then the inspection should be carried out annually.

STORMWATER POND BERM DETAIL

NOT TO SCALE



133 Court Street Portsmouth, NH 03801 (603) 433-2335 www.altus-eng.com



NOT FOR CONSTRUCTION

REVIEW

SSUED FOR:

<u>ISSUE DATE:</u>

OCTOBER 8, 2025

REVISIONS NO. DESCRIPTION BY DATE) REVIEW EBS 06/23/ REVISED PER COMMENTS EBS 10/08/2

DRAWN BY: _____ APPROVED BY: ____

DRAWING FILE: ____

24" x 36" - 1" = NTS $11" \times 17" - 1" = NTS$

5440-SITE.dwa

OWNER:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824


<u>APPLICANT:</u>

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

RIVERWOODS DURHAM PHASE II

TAX MAP 209 LOT 33 STONE QUARRY DRIVE & DOVER ROAD (NH 108) DURHAM, NH


DETAIL SHEET



NOTES:


- 1. SEE PLANS FOR CURB LOCATION. 2. ADJOINING STONES SHALL HAVE THE SAME OR APPROXIMATELY THE SAME
- 3. MINIMUM LENGTH OF CURB STONES = 3'4. MAXIMUM LENGTH OF CURB STONES = 10'
- 5. MAXIMUM LENGTH OF STRAIGHT CURB

m, man Eliverit et etti till etti
STONES LAID ON CURVES - SEE CHART.
CURB ENDS TO ROUNDED AND BATTERED
FACES TO BE CUT WHEN CALLED FOR
ON THE PLANS.





- 1. SEE SITE PLAN FOR LIMITS OF CURBING
- 2. ADJOINING STONES OF STRAIGHT CURB LAID ON CURVES SHALL HAVE THE SAME OR APPROXIMATELY THE SAME LENGTH
- 3. MINIMUM LENGTH OF STRAIGHT CURB STONES = 18"
- 4. MAXIMUM LENGTH OF STRAIGHT CURB STONES = 8
- 5. MAXIMUM LENGTH OF STRAIGHT CURB STONES LAID ON CURVES -SEE CHART

RADIUS FOR STONES	MAXIMUM
WITH SQUARE JOINTS	LENGTH
16'-28' 29'-41' 42'-55' 56'-68' 69'-82' 83'-96' 97'-110' OVER 110'	1'-6" 2' 3' 4' 5' 6' 7' 8'



HANDICAP PARKING STALL LAYOUT NOT TO SCALE






1. SYMBOL TO BE PAINTED IN ALL HANDICAPPED ACCESSIBLE SPACES IN WHITE PAINT (BLUE-PAINTED SQUARE BACKGROUND AND WHITE BORDER OPTIONAL).

PAINTED HANDICAP SYMBOL

NOT TO SCALE



NOT TO SCALE

RADIUS MAX. LENGTH

22'-28'

29'-35'

36'-42'

43'-49'

50'-56'

OVER 60'

SLOPED GRANITE CURB

NOT TO SCALE

CURB RAMP (TYPE 'A')

CONCRETE RAMP AND LANDING WITH

TRANSITION CURB

VERTICAL GRANITE CURB -

CURB TAPER TO MATCH

TRANSITION CURB PER

RAMP DETAIL (TYP) _/

WHERE SPECIFIED -


DETECTABLE WARNING

PANEL WHERE SPECIFIED -

NOT TO SCALE

CURB RAMP (TYPE 'B')

NOT TO SCALE



VERTICAL GRANITE CURB

SECTION


A-A

STRAIGHT

→ 3"MIN.

SECTION

GRANITE CURB



CURB RAMP (TYPE 'G')

NOT TO SCALE

FLUSH CURB LIP REVEAL AT RAMP END SHALL NOT

- SIDEWALK, RAMP AND

SUBGRADE PER PLANS

6"-WIDE (MIN) THICKENED

CONCRETE EDGE TO

FINISH GRADE

EXTEND 1' (MIN) BELOW

VERTICAL GRANITE CURB

PER DIMENSIONS IN CURB

EXCEED 1/2"

AND DETAILS


CURB RAMP (TYPE 'N')

NOT TO SCALE

NOTES APPLICABLE TO ALL CURB RAMPS:

- 1. THE MAXIMUM ALLOWABLE CROSS SLOPE OF AN ACCESSIBLE ROUTE (SIDEWALK) AND CURB SHALL
- 2. THE MAXIMUM ALLOWABLE RUNNING SLOPE OF AN ACCESSIBLE ROUTE (SIDEWALK) EXCLUDING CURB RAMPS SHALL BE 5% WITHOUT HANDRAILS.
- 3. THE MAXIMUM ALLOWABLE RUNNING SLOPE OF AN ACCESSIBLE ROUTE (SIDEWALK) CURB RAMP SHALL BE 8.3% FOR A MAXIMUM ELEVATION CHANGE OF 6".
- 4. CURB TREATMENT VARIES, SEE PLANS FOR CURB TYPE.
- 5. BASE OF RAMP SHALL BE GRADED TO PREVENT THE PONDING OF WATER (2% MAX. SLOPE).
- 6. SEE CONCRETE SIDEWALK SECTION FOR RAMP CONSTRUCTION.
- 7. ALL CURB RAMPS SHALL BE CONSTRUCTED IN ACCORDANCE WITH AMERICANS WITH DISABILITIES ACT (ADA) AND ALL APPLICABLE CODES.
- 8. FLUSH CURB SECTIONS SHALL HAVE A MAXIMUM LIP REVEAL OF 1/4" WITH A BEVEL AT THE EDGE
- 9. EDGES OF CONCRETE SIDEWALK FOOTINGS ALONG FLUSH CURBS SHALL BE HAUNCHED SO AS TO
- EXTEND TO A MINIMUM DEPTH OF 1' BELOW FINISH GRADE.
- 10. NO RAMP SHALL BE LESS THAN 4' IN WIDTH.
- 11. CURB RAMPS SHALL HAVE A FLAT 2% MAX. LANDING AT THE TOP AND BOTTOM OF THE RAMPS WHEN THERE IS A CHANGE IN DIRECTION.

NOT TO SCALE



STRAIGHT TO SLOPE CURB TRANSITION NOT TO SCALE

1. BASE-TO-BASE SPACING SHALL BE 0.65" MINIMUM BETWEEN DOMES. 2. WHERE SPECIFIED, SIDEWALK CURB RAMPS SHALL HAVE DETECTABLE WARNING SURFACES THAT EXTEND THE FULL WIDTH OF THE RAMP AND 2' DEPTH IN THE DIRECTION OF TRAVEL.

TRUNCATED DOME

0.9" MIN.

1.4" MAX.

- INTEGRAL DOME

- 3. THE TOP WIDTH OF THE DOME SHALL BE A MINIMUM OF 50% AND A MAXIMUM OF 65% OF THE BASE DIAMETER.
- 4. WARNING PANELS TO BE CAST IRON "IRON DOME" OR EQUAL.
- 5. PANEL SHALL BE INSTALLED SO THAT THE EDGE IS NO GREATER THAN 3" FROM THE CURB LINE OR GUTTER.

DETECTABLE WARNING PANEL NOT TO SCALE





PAVEMENT PER

RAMP WIDTH | PER PLANS |

NOT TO SCALE

CURB RAMP NOTES





NOT FOR CONSTRUCTION

REVIEW

ISSUED FOR:

<u>ISSUE DATE:</u>

OCTOBER 8, 2025

<u>REVISIONS</u> NO. DESCRIPTION O REVIEW EBS 06/23/ REVISED PER REVIEW EBS 10/08/2

DRAWN BY: APPROVED BY: ___ 5440-SITE.dwg DRAWING FILE: ___

24" x 36" - 1" = NTS 11" x 17" - 1" = NTS

OWNER:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

APPLICANT:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824


RIVERWOODS **DURHAM PHASE II**


> **TAX MAP 209 LOT 33** STONE QUARRY DRIVE & DOVER ROAD (NH 108) DURHAM, NH


TITLE:

DETAIL SHEET

SHEET NUMBER:







1. JOINTS IN CONCRETE SIDEWALKS SHALL CONFORM TO THE TYPES AND LOCATIONS SHOWN IN THE HEAVY—DUTY CONCRETE PAVEMENT DETAIL

CONCRETE SIDEWALK

NOT TO SCALE



TYPICAL TRENCH PATCH

EXCAVATED UTILITY TRENCH

EXISTING GRAVEL BEYOND

TRENCH SHALL BE LEFT

UNDISTURBED —

LIMIT OF TRENCH

EXCAVATION (TYP) -

SAWCUT EDGE (TYP) -----

SAWCUT EDGE (TYP) -

EXISTING GROUND

APPLICABLE)

CONSTRUCT BITUMINOUS

(SEE PAVEMENT SECTION) -

1. MACHINE CUT EXISTING PAVEMENT.

PERMANENT TRENCH REPAIRS.

CONCRETE PAVEMENT PATCH

TRENCH OR OTHER EXCAVATION

(SEE TRENCH SECTION WHERE

OVERLAP

(SEE TRENCH SECTION) -

EXISTING PAVEMENT -

SAWCUT JOINT TO BE COATED

IMMEDIATELY PRIOR TO PLACING PAVEMENT PATCH

-CLEAN VERTICAL EDGE OF

WITH RS-1 EMULSION

SECTION

2. ALL TEMPORARY, DAMAGED OR DEFECTIVE PAVEMENT SHALL BE REMOVED PRIOR TO PLACEMENT OF

3. DIAMOND PATCH SHALL BE REQUIRED FOR ALL TRENCHES CROSSING ROADWAYS AND SHALL MEET

NHDOT REQUIREMENTS UNLESS OTHERWISE SPECIFIED BY ENGINEER.


BOLLARD

W1-2R


(30")

W13-1P(15)

18" x 18"



BITUMINOUS SIDEWALK NOT TO SCALE



TYPICAL PAVEMENT SAWCUT

NOT TO SCALE

SIGN BOLLARD DETAIL

TYPICAL

ALUMINUM SIGN

(SEE PLAN FOR TYPE)

1-1/4"

ALUMINUM SIGN

(SEE PLAN FOR

TYPE)

NOT TO SCALE

- 6" Ø GALV. STEEL PIPE FILLED w/3000

INSTALLED OVER PIPE, COLOR AT OWNERS

3,000 PSI CYLINDRICAL

CONCRETE FOOTING

6" MIN. COMPACTED

SQUARE HOLLOW STRUCTURAL

7' (MIN.) CLEARANCE TO BE

REDUCED TO 5' ONLY WHERE

DIRECTED BY ENGINEER

TUBING SIGN POST

BOLLARD PER

· FINISH GRADE

R7-8

12" x 18"

VAN

ACCESSIBLE

R7-8P

18" x 9"

W11A - 2

(30")

W16 - 7P

BOLLARD DETAIL


3/4" CRUSHED STONE BASE

NOT TO SCALE

psi CONCRETE AND PVC SLEEVE

FINISH GRADE


DISCRETION



NOTES FOR STANDARD AND HEAVY DUTY ASPHALT PAVEMENT

- 1. PROJECT GEOTECHNICAL REPORT MAY REQUIRE A DIFFERENT PAVEMENT CROSS SECTION(S). THE CONTRACTOR SHALL BE RESPONSIBLE FOR READING AND FOLLOWING ALL RECOMMENDATIONS IN THE GEOTECHNICAL REPORT. IN THE EVENT THAT THE REPORT AND CIVIL PLANS DIFFER, THE MORE STRINGENT SPECIFICATION SHALL APPLY.
- 2. REMOVE ALL LOAM, CLAY, MUCK, ORGANIC, YIELDING OR OTHERWISE UNSTABLE MATERIAL TO A MINIMUM OF 24" BELOW FINISH GRADE. ADDITIONAL DEPTH MAY BE REQUIRED BY THE GEOTECHNICAL REPORT (IF AVAILABLE) OR THE ENGINEER. SUCH ADDITIONAL REMOVAL SHALL REQUIRE THE PLACEMENT OF COMPACTED SAND OR GRAVEL BORROW APPROVED BY THE ENGINEER TO THE BOTTOM OF SUBGRADE.
- 3. SUBGRADE SHALL BE PROOFROLLED A MINIMUM OF 6 PASSES WITH A 10-TON VIBRATORY COMPACTOR OPERATING AT PEAK RATED FREQUENCY OR BY MEANS APPROVED BY THE ENGINEER.
- 4. FILL BELOW PAVEMENT SUBGRADE SHALL BE SAND OR GRANULAR BORROW COMPACTED PER DOT REQUIREMENTS.
- 5. SITEWORK CONTRACTOR SHALL COORDINATE GEOTECHNICAL ENGINEERING INSPECTIONS WITH THE CONSTRUCTION MANAGER PRIOR TO PLACING GRAVELS.
- 6. BITUMINOUS PAVEMENT SHALL BE COMPACTED TO 90 TO 97 PERCENT OF ITS THEORETICAL MAXIMUM DENSITY AS DETERMINED BY ASTM D-2041. THE BASE AND SUBBASE MATERIALS SHOULD BE COMPACTED TO AT LEAST 95 PERCENT OF THEIR MAXIMUM DRY DENSITIES AS DETERMINED BY ASTM D-1557. COMPACTION TESTING SHALL BE PERFORMED BY A GEOTECHNICAL ENGINEER FOR ALL MATERIAL COURSES AND THE RESULTS APPROVED BY THE ENGINEER PRIOR TO PLACING THE SUBSEQUENT COURSE.
- 7. TACK COAT SHALL BE APPLIED BETWEEN SUCCESSIVE LIFTS OF ASPHALT.

STANDARD DUTY ASPHALT PAVEMENT NOT TO SCALE




PER DOT REQUIREMENTS.

- 1. EACH GRAVEL BASE COURSE TO BE CONSTRUCTED AT THE PAVEMENT CROSS SLOPE.
- 2. REMOVE LEDGE 18" BELOW LOWEST WORK BEING INSTALLED.
- 3. REMOVE ALL LOAM, CLAY, MUCK, ORGANIC, YIELDING OR OTHERWISE UNSTABLE MATERIAL TO A MINIMUM OF 24" BELOW FINISH GRADE. ADDITIONAL DEPTH MAY BE REQUIRED BY THE GEOTECHNICAL REPORT (IF AVAILABLE) OR THE ENGINEER. SUCH ADDITIONAL REMOVAL SHALL REQUIRE THE PLACEMENT OF COMPACTED SAND OR GRAVEL BORROW APPROVED BY THE ENGINEER TO THE BOTTOM OF SUBGRADE.
- 4. THE OVER-EXCAVATION OF UNSUITABLE MATERIAL BEYOND THAT SPECIFIED ABOVE, THE INSTALLATION OF UNDERDRAINAGE, AND/OR THE INSTALLATION OF GEOTEXTILE FABRIC SHALL BE PROVIDED UPON DETERMINATION OF THE ENGINEER.
- 5. FILL BELOW PAVEMENT SUBGRADE SHALL BE SAND OR GRANULAR BORROW COMPACTED
- 6. SITEWORK CONTRACTOR SHALL COORDINATE GEOTECHNICAL ENGINEERING INSPECTIONS PRIOR TO PLACING GRAVELS.
- 7. SUBGRADE SHALL BE FREE OF VOIDS THAT ALLOW MOVEMENT AND/OR SETTLEMENT OF MATERIALS.
- 8. SUBGRADE SHALL BE ROLLED WITH A MINIMUM OF SIX PASSES OF A 10-TON VIBRATORY COMPACTOR OPERATING AT PEAK RATED FREQUENCY OR BY OTHER MEANS APPROVED BY
- 9. SUBGRADE SHALL BE PROOF-ROLLED WITH A FULLY LOADED DUMP TRUCK PRIOR TO PLACEMENT OF SELECT GRAVELS. PROOF-ROLLING SHALL BE WITNESSED AND APPROVED BY THE ENGINEER.
- 10. BITUMINOUS PAVEMENT SHALL BE COMPACTED TO 90 TO 97 PERCENT OF ITS THEORETICAL MAXIMUM DENSITY AS DETERMINED BY ASTM D-2041. THE BASE AND SUBBASE MATERIALS SHOULD BE COMPACTED TO AT LEAST 95 PERCENT OF THEIR MAXIMUM DRY DENSITIES AS DETERMINED BY ASTM D-1557. COMPACTION TESTING SHALL BE PERFORMED BY A GEOTECHNICAL ENGINEER FOR ALL MATERIAL COURSES AND THE RESULTS APPROVED BY THE ENGINEER PRIOR TO PLACING THE SUBSEQUENT COURSE.
- 11. TACK COAT SHALL BE APPLIED BETWEEN SUCCESSIVE LIFTS OF ASPHALT PAVEMENT.

TYPICAL ROADWAY CROSS SECTION - STONE QUARRY DRIVE

NOT TO SCALE



REDUCE TO 5' ONLY

WHERE DIRECTED IN FIELD BY ENGINEER

WEIGHT PER LINEAR FOOT: 2.50 LBS (MIN.) HOLES: 3/8" DIAMETER, 1" C-C FULL LENGTH


LENGTH: AS REQUIRED

STEEL: SHALL CONFORM TO ASTM A-499 (GRADE 60) OR ASTM A-576 (GRADE 1070 - 1080)

<u>NOTES</u>

- 1. ALL SIGNS SHALL MEET THE REQUIREMENTS OF AND BE INSTALLED AS INDICATED IN THE MANUAL ON UNIFORM TRAFFIC CONTROL DEVICES, LATEST EDITION.
- WHEN PLACED PERPENDICULAR TO A TRAVELLED WAY OR SIDEWALK, SIGN EDGE SHALL BE NO CLOSER THAN 2' TO THE EDGE OF PAVEMENT. GREATER MINIMUM DISTANCE MAY BE REQUIRED IN CERTAIN LOCATIONS.

SIGN DETAILS NOT TO SCALE



Portsmouth, NH 03801 133 Court Street (603) 433-2335 www.altus-eng.com WEINRIEB

No. 7634

NOT FOR CONSTRUCTION

REVIEW

SSUED FOR:

ISSUE DATE:

OCTOBER 8, 2025

REVISIONS NO. DESCRIPTION BY DATE) REVIEW EBS 06/23/

REVISED PER COMMENTS EBS 10/08/2

DRAWN BY APPROVED BY: ____ 5440-SITE.dwa

DRAWING FILE: ____

24" x 36" - 1" = NTS $11" \times 17" - 1" = NTS$

OWNER:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824


<u>APPLICANT:</u>

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

RIVERWOODS DURHAM PHASE II

TAX MAP 209 LOT 33 STONE QUARRY DRIVE & DOVER ROAD (NH 108) DURHAM, NH

DETAIL SHEET



NON-PAVED AREA | PAVED AREA

" CLEAR (MIN)

3'-7" (MIN)

36 INCHES FOR PRIMARY CABLES AND 24 INCHES FOR SECONDARY CABLES.

51" MIN. UNDER SLAB

1. ALL CONDUIT IS TO BE SCHEDULE 40 PVC, ELECTRICAL GRADE, GRAY IN COLOR AND INSTALLED PER

STEEL CONDUIT WILL BE REQUIRED AT EACH SWEEP, UNLESS IN THE OPINION OF THE SERVICE

2. ALL 90 DEGREE SWEEPS WILL BE MADE WITH RIGID GALVANIZED STEEL WITH A MINIMUM RADIUS OF

3. BACKFILL MAY BE MADE WITH EXCAVATED MATERIAL OR COMPARABLE, UNLESS MATERIAL IS DEEMED

4. A SUITABLE PULLING STRING, CAPABLE OF 300 POUNDS OF PULL, MUST BE INSTALLED IN THE

6. TYPICAL CONDUIT SIZES ARE 3-INCH FOR SINGLE PHASE PRIMARY AND SECONDARY VOLTAGE CABLES, 4-INCH FOR THREE PHASE SECONDARY, AND 5-INCH FOR THREE PHASE PRIMARY.

SIZES, TYPES AND NUMBERS WITH EACH SERVICE PROVIDER PRIOR TO ORDERING THEM.

WITH ALL SERVICE PROVIDERS PRIOR TO THE INSTALLATION OF ANY CONDUIT.

USING PIPE STANCHIONS PLACED EVERY FIVE (5') FEET ALONG THE CONDUIT RUN.

CONDUIT BEFORE SERVICE PROVIDER IS NOTIFIED TO INSTALL CABLE. THE STRING SHOULD BE

UNSUITABLE BY SERVICE PROVIDER. BACKFILL SHALL BE FREE OF FROZEN LUMPS, ROCKS, DEBRIS, AND RUBBISH. ORGANIC MATERIAL SHALL NOT BE USED AS BACKFILL. BACKFILL SHALL BE IN

BLOWN INTO THE CONDUIT AFTER THE RUN IS ASSEMBLED TO AVOID BONDING THE STRING TO THE

SHALL BE NYLON ROPE HAVING A MINIMUM TENSILE STRENGTH OF THREE HUNDRED (300#) LBS.

5. SERVICE PROVIDER SHALL BE GIVEN THE OPPORTUNITY TO INSPECT ALL CONDUIT PRIOR TO BACKFILL. THE CONTRACTOR IS RESPONSIBLE FOR ALL REPAIRS SHOULD SERVICE PROVIDER BE UNABLE TO

HOWEVER, SERVICE PROVIDERS MAY REQUIRE DIFFERENT NUMBERS, TYPES AND SIZES OF CONDUIT THAN THOSE SHOWN HERE. THE CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING ALL CONDUIT

7. ROUTING OF CONDUIT, LOCATION OF MANHOLES, TRANSFORMERS, CABINETS, HANDHOLES, ETC., SHALL BE DETERMINED BY SERVICE PROVIDER DESIGN PERSONNEL. THE CONTRACTOR SHALL COORDINATE

8. ALL CONDUIT INSTALLATIONS MUST CONFORM TO THE CURRENT EDITION OF THE NATIONAL ELECTRIC SAFETY CODE, STATE AND LOCAL CODES AND ORDINANCES, AND WHERE APPLICABLE, THE NATIONAL

ELECTRIC CODE. WHERE REQUIRED BY UTILITY PROVIDER, CONDUIT SHALL BE SUPPORTED IN PLACE

CONDUIT. A MINIMUM OF TWENTY-FOUR (24") INCHES OF ROPE SLACK SHALL REMAIN AT THE END

OF EACH DUCT. PULL ROPE SHALL BE INSTALLED IN ALL CONDUIT FOR FUTURE PULLS. PULL ROPE

THE MANUFACTURER'S RECOMMENDATIONS. A 10-FOOT HORIZONTAL SECTION OF RIGID GALVANIZED

PROVIDER DESIGNER, THE SWEEP-PVC JOINT IS NOT SUBJECT TO FAILURE DURING PULLING OF THE

12"

MAGNETIC WARNING TAPE

SCH. 40 CONDUIT

(SIZE AND

REQUIRED)

CABLE. ALL JOINTS ARE TO BE WATERTIGHT.

6-INCH LAYERS AND THOROUGHLY COMPACTED.

INSTALL ITS CABLE IN A SUITABLE MANNER.

QUÀNTITY AS

(12" ABOVE EA. CONDUIT) -

- SEE ROADWAY CROSS-SECTION

1/2"

CLEAN GRANULAR BACKFILL

MATERIAL COMPACTED AS

SELECT SAND COMPACTED TO

(ADJUST BEDDING AS SPECIFIED

95% STANDARD PROCTOR

IN GEOTECH REPORT)

SPECIFIED

SAND BLANKET/BARRIER

SIEVE SIZE % FINER BY WEIGHT

90 - 100

0 - 15

OR BUILDING PAD DETAILS


-SEE PAVEMENT CAUTION TAPE -SECTION FINISH GRADE EXCAVATION AND BACKFILL IN ACCORDANCE WITH UTILITY COMPANY STANDARDS -GAS PIPELINE MATERIAL AND INSTALLATION BY UTILITY COMPANY (TRACER WIRE IF REQUIRED) --SAND BEDDING OR AS SPECIFIED BY UTILITY COMPANY (ADJUST BEDDING AS SPECIFIED IN GEOTECH REPORT)

SAND BLA	NKET/BARRIER
SIEVE SIZE	% FINER BY WEIG
1/2"	90 - 100
200	0 - 15

<u>NOTES</u>

- 1. CONTRACTOR TO COORDINATE WITH UTILITY COMPANY AND PROVIDE ALL EXCAVATION, COMPACTION AND BACKFILL REQUIRED FOR PIPE INSTALLATION.
- 2. BACKFILL MATERIAL BELOW PAVED OR CONCRETE AREAS, BEDDING MATERIAL, AND SAND BLANKET SHALL BE COMPACTED TO NOT LESS THAN 95% OF AASHTO T 99, METHOD C. SUITABLE BACKFILL MATERIAL BELOW LOAM AREAS SHALL BE COMPACTED TO NOT LESS THAN 90% OF AASHTO T 99, METHOD C.

GAS TRENCH NOT TO SCALE



NOT

- BACKFILL MATERIAL BELOW PAVED OR CONCRETE AREAS, BEDDING MATERIAL, AND SAND BLANKET SHALL BE COMPACTED TO NOT LESS THAN 95% OF AASHTO T 99, METHOD C. SUITABLE BACKFILL MATERIAL BELOW LOAM AREAS SHALL BE COMPACTED TO NOT LESS THAN 90% OF AASHTO T 99, METHOD C.
- 2. INSULATE GRAVITY SEWER AND FORCEMAINS WHERE THERE IS LESS THAN 5'-0" OF COVER WITH 2" THICK CLOSED CELL RIGID BOARD INSULATION, 18" ON EACH SIDE OF PIPE.
- 3. MAINTAIN 12" MINIMUM HORIZONTAL SEPARATION AND WIDEN TRENCH ACCORDINGLY IF MULTIPLE PIPES ARE IN TRENCH.

<u>sand e</u>	BLANKET/BARRIER	SCREENED GRAVEL C	OR CRUSHED STONE BEDDING*
SIEVE SIZE	% FINER BY WEIGHT	SIEVE SIZE	% PASSING BY WEIGHT
1/2" 200	90 - 100 0 - 15	1" 3/4" 3/8" # 4 # 8	100 90 - 100 20 - 55 0 - 10 0 - 5
		* EQUIVALENT TO STAND SECTION 703 OF NHDC	ARD STONE SIZE #67 — OT STANDARD SPECIFICATIONS

10. ALL CONDUIT TERMINATIONS SHALL BE CAPPED TO PREVENT DEBRIS FROM ENTERING CONDUIT.

ELECTRIC / COMMUNICATION TRENCH NOT TO SCALE

9. UNDER A BUILDING SLAB THE CONDUIT SHALL BE ENCASED IN 8" OF CONCRETE ON ALL SIDES.

DRAINAGE TRENCH NOT TO SCALE


STANDARD TRENCH NOTES 1. ORDERED EXCAVATION OF UNSUITABLE

- 1. ORDERED EXCAVATION OF UNSUITABLE MATERIAL BELOW GRADE: BACKFILL AS STATED IN THE TECHNICAL SPECIFICATIONS OR AS SHOWN ON THE DRAWING.
- 2. BEDDING: SCREENED GRAVEL AND/OR CRUSHED STONE FREE FROM CLAY, LOAM, ORGANIC MATTER AND MEETING THE GRADATION SHOWN IN THE TRENCH DETAIL. WHERE ORDERED BY THE ENGINEER TO STABILIZE THE BASE, SCREENED GRAVEL OR CRUSHED STONE 1-1/2 INCH TO 1/2 INCH SHALL BE USED.
- 3. SAND BLANKET: CLEAN SAND FREE FROM ORGANIC MATTER MEETING THE GRADATION SHOWN IN THE TRENCH DETAIL. BLANKET MAY BE REPLACED WITH BEDDING MATERIAL FOR CAST—IRON, DUCTILE IRON, AND REINFORCED CONCRETE PIPE PROVIDED THAT NO STONE LARGER THAN 2" IS IN CONTACT WITH THE PIPE AND THE GEOTEXTILE IS RELOCATED ACCORDINGLY.
- 4. SUITABLE MATERIAL: IN ROADS, ROAD SHOULDERS, WALKWAYS AND TRAVELED WAYS, SUITABLE MATERIAL FOR TRENCH BACKFILL SHALL BE THE NATURAL MATERIAL EXCAVATED DURING THE COURSE OF CONSTRUCTION, BUT SHALL EXCLUDE DEBRIS, PIECES OF PAVEMENT, ORGANIC MATTER, TOP SOIL, ALL WET OR SOFT MUCK, PEAT, OR CLAY, ALL EXCAVATED LEDGE MATERIAL, ALL ROCKS OVER 6 INCHES IN LARGEST DIMENSION, AND ANY MATERIAL WHICH, AS DETERMINED BY THE ENGINEER, WILL NOT PROVIDE SUFFICIENT SUPPORT OR MAINTAIN THE COMPLETED CONSTRUCTION IN A STABLE CONDITION. IN CROSS COUNTRY CONSTRUCTION, SUITABLE MATERIAL SHALL BE AS DESCRIBED ABOVE, EXCEPT THAT THE ENGINEER MAY PERMIT THE USE OF TOP SOIL, LOAM, MUCK, OR PEAT ONLY IF SATISFIED THAT THE COMPLETED CONSTRUCTION WILL BE ENTIRELY STABLE AND PROVIDED THAT EASY ACCESS TO THE SEWER FOR MAINTENANCE AND POSSIBLE RECONSTRUCTION WILL BE PRESERVED.
- 5. BASE COURSE AND PAVEMENT SHALL MEET THE REQUIREMENTS OF THE NEW HAMPSHIRE DEPARTMENT OF TRANSPORTATION'S LATEST EDITION OF THE STANDARD SPECIFICATIONS FOR HIGHWAYS AND BRIDGES DIVISIONS 300 AND 400 RESPECTIVELY.
- 6. W = MAXIMUM ALLOWABLE TRENCH WIDTH TO A PLANE 12 INCHES ABOVE THE PIPE. FOR PIPES 15 INCHES NOMINAL DIAMETER OR LESS, W SHALL BE NO MORE THAN 36 INCHES. FOR PIPES GREATER THAN 15 INCHES IN NOMINAL DIAMETER, W SHALL BE 24 INCHES PLUS PIPE OUTSIDE DIAMETER (O.D.) ALSO, W SHALL BE THE PAYMENT WIDTH FOR LEDGE EXCAVATION AND FOR ORDERED EXCAVATION BELOW GRADE.
- 7. FOR CROSS COUNTRY CONSTRUCTION, BACKFILL, FILL AND/OR LOAM SHALL BE MOUNDED TO A HEIGHT OF 6 INCHES ABOVE THE ORIGINAL GROUND SURFACE.
- 8. CONCRETE FOR ENCASEMENT SHALL CONFORM TO THE NEW HAMPSHIRE DOT STANDARD SPECIFICATION REQUIREMENTS FOR CLASS A (3000#) CONCRETE AS FOLLOWS:

 CEMENT: 6.0 BAGS PER CUBIC YARD

 WATER: 5.75 GALLONS PER BAG
- CEMENT MAXIMUM SIZE OF AGGREGATE: 1 INCH CONCRETE ENCASEMENT IS <u>NOT</u> ALLOWED FOR PVC PIPE.
- 9. CONCRETE FULL ENCASEMENT: IF FULL ENCASEMENT IS UTILIZED, DEPTH OF CONCRETE BELOW PIPE SHALL BE 1/4 I.D. (4" MINIMUM). BLOCK SUPPORT SHALL BE SOLID CONCRETE BLOCKS.
- 10. NEW HAMPSHIRE DEPARTMENT OF ENVIRONMENTAL SERVICES DESIGN STANDARDS REQUIRE TEN FEET (10') SEPARATION BETWEEN WATER AND SEWER. REFER TO CITY STANDARD SPECIFICATIONS FOR METHODS OF PROTECTION IN AREAS THAT CANNOT MEET THESE REQUIREMENTS.
- 11. THE CONTRACTOR SHALL INSTALL TRENCH DAMS IN ACCORDANCE WITH NHDES REGULATIONS.
- 12. SEWER TRENCHES SHALL BE CONSTRUCRTED IN ACCORANCE WITH NHDES STANDARDS OF DESIGN AND CONSTRUCTION FOR SEWAGE AND WASTEWATER FACILITES, LATEST EDITION.
- 13. ALL GRAVITY SEWER INSTALLATIONS SHALL BE TESTED IN ACCORDANCE WITH NHDES ENV-WQ

SEWER TRENCH NOT TO SCALE



NON-PAVED AREA |

3'-0" (MIN) OR D+2

FOR SINGLE PIPE

1. BACKFILL MATERIAL BELOW PAVED OR CONCRETE AREAS, BEDDING MATERIAL, AND SAND BLANKET

SHALL BE COMPACTED TO NOT LESS THAN 95% OF AASHTO T 99, METHOD C. SUITABLE BACKFILL

MATERIAL BELOW LOAM AREAS SHALL BE COMPACTED TO NOT LESS THAN 90% OF AASHTO T 99,

2. INSULATE GRAVITY SEWER AND FORCEMAINS WHERE THERE IS LESS THAN 5'-0" OF COVER WITH 2"

3. MAINTAIN 12" MINIMUM HORIZONTAL SEPARATION AND WIDEN TRENCH ACCORDINGLY IF MULTIPLE PIPES

THICK CLOSED CELL RIGID BOARD INSULATION, 18" ON EACH SIDE OF PIPE.

(WHICHEVER IS GREATER)

6" COMPACTED LOAM AND SEED OR

OTHER SURFACE TREATMENT PER PLANS -

EXCAVATED BACKFILL

OR CLEAN GRANULAR

"CAUTION - WARNING"

NON-WOVEN GEOTEXTILE

ARE IN TRENCH.

SIEVE SIZE

200

SAND BLANKET/BARRIER

% FINER BY WEIGHT

90 - 100

0 - 15

A.O.S.=70 OR LESS

BACKFILL MATERIAL

COMPACTED AS

TAPE 18" BELOW

SPECIFIED

SURFACE -

COMPACTED

NATIVE SOIL -

PAVED AREA

- SEE PAVEMENT SECTION

— SEE PAVEMENT SECTION

3/4" CRUSHED STONE

OF THE TRENCH

- ROCK SUBGRADE

(TEMPLATE)

SCREENED GRAVEL OR CRUSHED STONE BEDDING

* EQUIVALENT TO STANDARD STONE SIZE #67 -

SECTION 703 OF NHDOT STANDARD SPECIFICATIONS

3/4"

3/8"

% PASSING BY WEIGHT

100

90 - 100

20 - 55

0 - 10

0 - 5

BEDDING FOR FULL WIDTH

6" BELOW PIPE IN EARTH

12" BELOW PIPE IN ROCK


SEE PAVEMENT SECTION

SAND BLAN	IKET/BARRIER
SIEVE SIZE	% FINER BY WEIGH
1/2"	90 — 100
200	0 - 15

<u>NOTES</u>

- 1. BACKFILL MATERIAL BELOW PAVED OR CONCRETE AREAS, BEDDING MATERIAL, AND SAND BLANKET SHALL BE COMPACTED TO NOT LESS THAN 95% OF AASHTO T 99, METHOD C. SUITABLE BACKFILL MATERIAL BELOW LOAM AREAS SHALL BE COMPACTED TO NOT LESS THAN 90% OF AASHTO T 99, METHOD C
- 2. ALL TRENCHING AND BACKFILL SHALL CONFORM WITH THE STANDARDS OF THE DURHAM DPW.

WATER MAIN TRENCH NOT TO SCALE




SAND BLA	NKET/BARRIER
SIEVE SIZE	% FINER BY WEIGH
1/2"	90 - 100
200	0 - 15

NOTES


- 1. CONTRACTOR TO COORDINATE WITH MEP PLANS AND ELECTRICIAN AND PROVIDE ALL EXCAVATION, COMPACTION AND BACKFILL REQUIRED FOR CONDUIT INSTALLATION.
- 2. BACKFILL MATERIAL BELOW PAVED OR CONCRETE AREAS, BEDDING MATERIAL, AND SAND BLANKET SHALL BE COMPACTED TO NOT LESS THAN 95% OF AASHTO T 99, METHOD C. SUITABLE BACKFILL ALL MATERIAL BELOW LOAM AREAS SHALL BE COMPACTED TO NOT LESS THAN 90% OF AASHTO T 99, METHOD C.

LIGHTING TRENCH SECTION

NOT TO SCALE



133 Court Street Portsmouth, NH 03801 (603) 433-2335 www.altus-eng.com



NOT FOR CONSTRUCTION

REVIEW

ISSUED FOR:

ISSUED FOR

ISSUE DATE:

OCTOBER 8, 2025

REVISIONS
NO. DESCRIPTION
BY
DATE

O REVIEW
1 REVISED PER COMMENTS EBS 10/08/2

DRAWN BY: _____EBS

DRAWING FILE: ___

SCAL

24" x 36" - 1" = NTS 11" x 17" - 1" = NTS

5440-SITE.dwa

<u>OWNER:</u>

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

APPLICANT:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

PROJECT:


RIVERWOODS DURHAM PHASE II

TAX MAP 209 LOT 33 STONE QUARRY DRIVE & DOVER ROAD (NH 108) DURHAM, NH

ITI F·

DETAIL SHEET

SHEET NUMBER:




- 2" RIGID INSULATION WHERE PIPE COVER IS LESS THAN 5' WATER LINE 24" PREFERRED (18" MINIMUM) SEWER PIPE

- 1. A MINIMUM HORIZONTAL DISTANCE OF 10 FEET SHALL BE MAINTAINED BETWEEN WATER AND SEWER MAINS. A MINIMUM VERTICAL DISTANCE WITH WATER ABOVE SEWER SHALL BE MAINTAINED.
- 2. SEWER PIPE JOINTS SHALL BE LOCATED A MINIMUM OF 6 FEET HORIZONTALLY FROM WATER MAIN.
- 3. IF THE REQUIRED CONFIGURATION CANNOT BE MET, THE SEWER MAIN SHALL BE CONSTRUCTED TO MEET THE NHDES REQUIREMENTS FOR FORCE MAIN CONSTRUCTION.

WATER MAIN / SEWER CROSSING


NOT TO SCALE



NOTE: ALL GASKETS, SEALANTS, MORTAR, ETC. SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURERS WRITTEN INSTRUCTIONS.

SEWER MANHOLE DETAIL B


NOT TO SCALE




NOTE: ALL GASKETS, SEALANTS, MORTAR, ETC. SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURERS WRITTEN INSTRUCTIONS.

SEWER MANHOLE DETAIL A


NOT TO SCALE



(OR EQUAL)



LOCK-JOINT FLEXIBLE MANHOLE SLEEVE (OR EQUAL)



DRAWN BY: ___ APPROVED BY: ___ 5440-SITE.dwg DRAWING FILE: ___

SCALE:

24" x 36" - 1" = NTS $11" \times 17" - 1" = NTS$

Portsmouth, NH 03801

www.altus-eng.com

No. 7634

NOT FOR CONSTRUCTION

REVISED PER COMMENTS EBS 10/08/2

REVIEW

EBS 06/23/

OCTOBER 8, 2025

ISSUED FOR:

ISSUE DATE:

REVISIONS

O REVIEW

NO. DESCRIPTION

133 Court Street

(603) 433-2335

OWNER:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

<u>APPLICANT:</u>

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

RIVERWOODS **DURHAM PHASE II**


> **TAX MAP 209 LOT 33** STONE QUARRY DRIVE & DOVER ROAD (NH 108) DURHAM, NH

TITLE:

DETAIL SHEET

SHEET NUMBER:


C-19




MANHOLE NOTES:


- 1. IT IS THE INTENTION OF THE NHDES THAT THE MANHOLE, INCLUDING ALL COMPONENT PARTS, HAVE ADEQUATE SPACE, STRENGTH AND LEAKPROOF QUALITIES CONSIDERED NECESSARY BY THE COMMISSION FOR THE INTENDED SERVICE. SPACE REQUIREMENTS AND CONFIGURATIONS, SHALL BE AS SHOWN ON THE DRAWING. MANHOLES MAY BE AN ASSEMBLY OF PRECAST SECTIONS, WITH OR WITHOUT STEEL REINFORCEMENT, WITH ADEQUATE JOINTING, OR CONCRETE CAST MONOLITHICALLY IN PLACE WITH OR WITHOUT REINFORCEMENT IN ANY APPROVED MANHOLE. THE COMPLETE STRUCTURE SHALL BE OF SUCH MATERIAL AND QUALITY AS TO WITHSTAND LOADS OF 8 TONS (H-20 LOADING) WITHOUT FAILURE AND PREVENT LEAKAGE IN EXCESS OF ONE GALLON PER DAY PER VERTICAL FOOT OF MANHOLE CONTINUOUSLY FOR THE LIFE OF THE STRUCTURE, A PERIOD GENERALLY IN EXCESS OF 25 YEARS IS TO BE UNDERSTOOD IN BOTH CASES.
- 2. BARRELS AND CONE SECTIONS SHALL BE PRECAST REINFORCED.
- 3. PRECAST CONCRETE BARREL SECTIONS, CONES AND BASES SHALL CONFORM TO ASTM C478.
- 4. LEAKAGE TEST SHALL BE PERFORMED IN ACCORDANCE WITH THE TOWN'S STANDARD SPECIFICATIONS AND WITH NHDES Env-Wq 704.17.
- 5. INVERTS AND SHELVES MANHOLES SHALL HAVE A BRICK PAVED SHELF AND INVERT CONSTRUCTED TO CONFORM TO THE SIZE OF PIPE AND FLOW AT CHANGES IN DIRECTION. THE INVERTS SHALL BE LAID OUT IN CURVES, OF THE LONGEST RADIUS POSSIBLE TANGENT TO THE CENTER LINE OF THE SEWER PIPES. SHELVES SHALL BE CONSTRUCTED TO THE ELEVATION OF THE HIGHEST PIPE CROWN AND SLOPE TO DRAIN TOWARD THE FLOWING THROUGH CHANNEL. UNDERLAYMENT OF INVERT AND SHELF SHALL CONSIST OF BRICK MASONRY. BRICK MASONRY SHALL CONFORM WITH ASTM C32.
- 6. MORTAR MORTAR USED FOR MANHOLE CONSTRUCTION SHALL CONFORM WITH NHDES Env-Wq 704.13.
- 7. FRAMES AND COVERS MANHOLE FRAMES AND COVERS SHALL CONFORM WITH ASTM A48/48M, BE OF HEAVY DUTY DESIGN AND PROVIDE A 30-INCH CLEAR OPENING. A 3-INCH (MINIMUM HEIGHT) LETTER "S" OR "SEWER" FOR SEWERS OR "D" OR "DRAIN" FOR DRAINS SHALL BE PLAINLY CAST INTO THE CENTER OF EACH COVER.
- 8. <u>BEDDING</u> SCREENED GRAVEL AND/OR CRUSHED STONE FREE FROM CLAY, LOAM, ORGANIC MATTER AND MEETING ASTM C33. 100% PASSING 1 INCH SCREEN 0-10% PASSING #4 SIEVE 90-100% PASSING 3/4 INCH SCREEN 0-5% PASSING #8 SIEVE
- 20- 55% PASSING 3/8 INCH SCREEN WHERE ORDERED BY THE ENGINEER TO STABILIZE THE BASE, SCREENED GRAVEL OR CRUSHED STONE 1-1/2" TO 1/2" SHALL BE USED.
- 9. CONCRETE FOR DROP SUPPORT SHALL CONFORM TO THE REQUIREMENT FOR CLASS A (3000 LBS.) CONCRETE OF THE NEW HAMPSHIRE DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS AS FOLLOWS:
 - CEMENT 6.0 BAGS PER CUBIC YARD WATER 5.75 GALLONS PER BAG CEMENT MAXIMUM SIZE OF AGGREGATE 1 INCH 9.
- 10. FLEXIBLE JOINT A FLEXIBLE JOINT SHALL BE PROVIDED WITHIN THE FOLLOWING DISTANCES: PVC PIPE - 60"
 - RCP & CI PIPE ALL SIZES 48" AC & VC PIPE - UP THROUGH 12" DIAMETER - 18" AC & VC PIPE - LARGER THAN 12" DIAMETER - 36"
- 11. SHALLOW MANHOLE IN LIEU OF A CONE SECTION, WHEN MANHOLE DEPTH IS LESS THAN 6 FEET, A REINFORCED CONCRETE SLAB COVER MAY BE USED HAVING AN ECCENTRIC ENTRANCE OPENING AND CAPABLE OF SUPPORTING H-20 LOADS.

NOT TO SCALE





SEWER CLEANOUT NOT TO SCALE



DEEP SEWER SERVICE CONNECTION NOT TO SCALE

PUMP STATION SPECIFICATIONS

BOOT KOR-N-SEAL

OR EQUAL (TYP) -

6" SDR 35 INLET

Furnish and install pump station as shown on the plans. Station shall include, but not be limited to, a concrete pump chamber, pump, slide rail assemblies, duplex controller, access covers discharge piping, fittings, valves, junction box, level sensors, alarms, electric service, level controls, etc. All wiring shall be in compliance with Town of Durham codes.

PUMP CHAMBER: Pump chamber shall be an 5-foot inside diameter precast concrete pump chamber to the depth shown on the Drawings. Chamber shall be rated for H-20 loading.

The access covers shall be rigidly constructed to provide an H-20 rating with a 2'-6" X 4'-0" clear opening, maufactured by Syracuse Castings or approved equal. Cover shall be sealed with neoprene seal at openings and have hinges constructed of 316 stainless steel.

- GATE VALVE CLOSED) 30"x48" H−20 LOADING ALUMINUM ACCESS COVER FLOAT RACK 4" SCH 40 PVC VENT TO BUILDING STACK COORDINATE w/ MEP PLANS ___ FORCE MAIN PRECAST CONCRETE

LEAD PUMP ON ELEV 46.75

PUMPS OFF ELEV 46.25

SUMP ELEV 45.25

Pump shall be supplied to operate at the following range of flow vs. TDH: Flow of 170 gpm with a total dynamic head of 9.0'. Provide pump motor with adequate horsepower to deliver flows at the TDH required to reach the receiving point, taking into account the manufacturer's rated efficiency. Motor shall be 1—phase, 60 Cycle 1,750 rpm. Pump shall be submersible non—clog solids—handling sewage pump with 2" discharge as specified by the manufacturer and approved by the Engineer. Impeller shall have a diameter of 4.75" (121mm). Pump shall be Barnes SE-411 (0.4 hp) or approved equal. Provide discharge piping assembly for installation and removal of pump without entering wetwell with

stainless steel lift—out rail system.

Duplex control to perform equal alternation of both pumps. Control to consist of two circuit breakers with through—door operating handle, two magnetic starters with ambient compensated quick—trip overloads in each line, discharge piping by manufacturer, duplex unit, running lights, lightening arrestor, door-mounted resets, hour meters, and door-mounted hand-off-automatic selector switches for each pump. Enclosure to include continuous hinge, neoprene gasket in cover and continuous seam weld. Controller shall be Barnes Single Phase Duplex Alternating Control Panel 106484 or approved equal. The controls shall be NEMA 4x weathertight construction and mounted on a pedestal adjacent to Pump chamber, on a building, or on nearby utility pole. All conduit and wiring between the station junction boxes and control panel shall be included.

The slide rail assembly, mounting hardware, and lifting chain shall be AISI Type 316 stainless steel. Slide rails to be provided with AISI Type 316 stainless guide supports. Discharge coupling to be machined cast iron and support the pump four (4) inches above the floor.

ELECTRIC HANDHOLE

The discharge pipe shall be two (2") inch diameter SDR 11 PVC pipe. All fittings shall be cemented or threaded. PVC Ball check valves shall be provided with teflon seats. The working pressure of the check valves shall be 150 psi.

Four (4) liquid level control sensors shall be provided to control operation of the pumps and provide a high water alarm. The level control sensors shall be mounted on a PVC pipe. The controls shall be

set at elevations shown on the plans and for a dosage rate of 105.75 gallons.


Alarm shall be exterior mounted audio and visual in a location as determined by the Owner.

Contractor shall provide a sign for identification.

105.75 gallons per dose Design flow 170 GPD / 105.75 = \pm 1.6 doses per day

OWNER'S MAINTENANCE NOTES

1. PUMP CHAMBER TO BE PUMPED ANNUALLY BY A LICENSED SANITARY DISPOSAL CONTRACTOR.



SIMLEX PUMP STATION

DRAW DOWN = 147

GAL/VERTICAL FOOT DOSING = 74.5 GAL.

TYPICAL SECTION NOT TO SCALE

SLIDEAWAY

- CONCRETE FILLET

12" MIN. BEYOND

COMPACTED NATIVE

- 12" 3/4" CRUSHED STONE BASE

STRUCTURE

COUPLING

1. STYLE "DT-HD" ACCESS HATCH, AS MANUFACTURED BY SYRACUSE CASTINGS, CICERO, NEW YORK (315-699-2601) OR APPROVED EQUAL.

2. MATERIAL SHALL BE 6061-T6 ALUMINUM FOR BARS, ANGLES, AND EXTRUSIONS. 1/4" DIAMOND

3. UNIT DESIGNED HEAVY DUTY, FOR H-20 WHEEL LOADS, WHERE NOT SUBJECT TO HIGH DENSITY TRAFFIC. FRAME AND BEARING PLATE MUST BE CAST INTO AND SUPPORTED BY CONCRETE DESIGNED

4. UNIT SUPPLIED WITH A HEAVY DUTY PNEU-SPRING, FOR EASE OF OPERATION WHEN OPENING COVER. COVER SHALL BE COUNTERBALANCED, SO ONE PERSON CAN EASILY OPEN THE HATCH DOOR.

5. FRAME SHALL BE OF EXTRUDED ALUMINUM WITH A CONTINUOUS 1-1/4" ANCHOR FLANGE. A DOVETAIL GROOVE SHALL BE EXTRUDED INTO THE SEAT OF THE FRAME FOR A 1/8" SILICONE GASKET.

6. EACH HATCH SHALL BE EQUIPPED WITH A STAINLESS STEEL HOLD OPEN ARM. DOOR SHALL LOCK OPEN IN THE 90 DEGREE POSITION. HOLD OPEN ARM SHALL BE FASTENED TO THE FRAME WITH A 1/2"


7. HINGES SHALL BE OF HEAVY DUTY DESIGN. MATERIAL SHALL BE GRADE 316 STAINLESS STEEL. EACH HINGE SHALL HAVE A GRADE 316 STAINLESS STEEL, 3/8" DIAMETER HINGE PIN. HINGE SHALL BE FASTENED TO THE CHANNEL FRAME AND DIAMOND PLATE WITH GRADE 316 STAINLESS STEEL BOLTS AND


8. ALUMINUM SHALL BE SUPPLIED WITH MILL FINISH. EXTERIOR OF FRAME WHICH COMES IN CONTACT WITH CONCRETE SHALL HAVE ONE COAT BLACK PRIMER.


9. EACH HATCH SHALL BE SUPPLIED WITH A STAINLESS STEEL SLAM LOCK, WITH THE KEY WAY PROTECTED BY A THREADED ALUMINUM PLUG. THE PLUG SHALL BE FLUSH WITH THE TOP OF THE 1/4" DIAMOND PLATE. THE SLAM LOCK SHALL BE FASTENED WITH GRADE 316 STAINLESS STEEL BOLTS AND

10. EACH HATCH SHALL BE EQUIPPED WITH A STAINLESS STEEL LIFT HANDLE. LIFT HANDLE SHALL BE FLUSH WITH TOP OF 1/4" DIAMOND PLATE.


11. EACH "DT-HD" STYLE HATCH IS SUPPLIED WITH A 1-1/2" THREADED DRAIN COUPLER ON THE UNDERSIDE OF CHANNEL FRAME, FOR PIPE CONNECTION.








SINGLE LEAF H-20 ALUMINUM HATCH NOT TO SCALE



Portsmouth, NH 03801 133 Court Street (603) 433-2335 www.altus-eng.com



NOT FOR CONSTRUCTION

REVIEW

ISSUED FOR:

<u>ISSUE DATE:</u>

OCTOBER 8, 2025

<u>REVISIONS</u> NO. DESCRIPTION O REVIEW EBS 06/23/ REVISED PER COMMENTS EBS 10/08/2

DRAWN BY: APPROVED BY: ___

DRAWING FILE: ___

SCALE:

24" x 36" - 1" = NTS $11" \times 17" - 1" = NTS$

5440-SITE.dwa

OWNER:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

APPLICANT:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

RIVERWOODS DURHAM PHASE II


TAX MAP 209 LOT 33 STONE QUARRY DRIVE & DOVER ROAD (NH 108) DURHAM, NH

TITLE:

DETAIL SHEET


SHEET NUMBER:





DIA.) 6-7" 3'-0" | 1'-11" | 2'-3" | 5'-0" | 4'-6" | 3'-10" | 1'-6 5'-4"


CONCRETE HEADWALL w/WINGWALLS NOT TO SCALE



PROPOSED RIPRAP

PROPOSED RAINGARDEN


PROPOSED POROUS PAVEMENT




NOTES:

- 1. TYPICAL MODULAR BLOCK SHALL BE PRECAST CONCRETE MEASURING APPROXIMATELY 16"x12"x6". OTHER BLOCK SIZES MAY BE APPROVED BY THE ENGINEER UPON REQUEST. CAP UNITS SHALL BE PER THE STANDARDS OF THE SELECTED MANUFACTURER.
- 2. WALL SHALL BE INSTALLED PER THE REQUIREMENTS OF THE MANUFACTURER.
- 3. WALL HEIGHT SHALL NOT EXCEED 4' WITHOUT DESIGN DRAWINGS STAMPED BY A NEW HAMPSHIRE LICENSED PROFESSIONAL STRUCTURAL ENGINEER FAMILIAR WITH WALL DESIGN.
- 4. LOCKING PINS MAY OR MAY NOT BE REQUIRED BASED ON THE WALL MANUFACTURER APPROVED BY
- 5. WALL SHALL BE EMBEDDED BELOW EXISTING GRADE THE DEPTH OF AT LEAST ONE BLOCK UNLESS OTHERWISE SPECIFIED BY THE WALL MANUFACTURER.
- 6. WALL BATTER SHALL BE PER THE MANUFACTURER'S SPECIFICATIONS.
- 7. BLOCK FINISH SHALL BE AT THE DISCRETION OF THE OWNER.
- 8. MODULAR BLOCK RETAINING WALL SHALL BE VERSA-LOK RETAINING WALL SYSTEMS (OR EQUAL APPROVED BY THE ENGINEER PRIOR TO INSTALLATION).

MODULAR BLOCK RETAINING WALL NOT TO SCALE







NOTES:

- 1. GATE VALVES SHALL OPEN RIGHT, PER CITY STANDARDS.
- 2. BRANCH PIPING SHALL BE MECHANICALLY RESTRAINED AS NOTED UNDER THRUST BLOCK DETAIL REQUIREMENTS.


TEE & GATE VALVE ASSEMBLY

NOT TO SCALE





BOCCE COURT CROSS SECTION



WATER MAIN

1'-0" MIN.

-CORP. STOP (FORD OR

└-1.5" (TYP.) TYPE "K"

VALVE BOX (TYP.)

COPPER SERVICE LINE

CURB STOP W/2-1/2" C.I.

(FORD OR APPROVED EQUAL) —

NOTE: ALL CURB AND CORP. STOPS TO

NOTE: ALL MATERIALS AND SPECIFICATIONS SHALL CONFORM TO

CITY OF PORTSMOUTH WATER DEPARTMENT STANDARDS

BE COMPRESSION-JOINT TYPE.

APPROVED EQUAL)

WATER SERVICE CONNECTION

NOT TO SCALE

GOOSENECK

(TYPICAL)

CONTRACT

EDGE OF

CAP & WITNESS

AT OR BEYOND


CONTRACT LIMIT

AS SHOWN ON

THE PLANS.

PAVEMENT

| 1' MIN. |




NOT TO SCALE

50 psi		ARE FEET OF				/ATERIA	\L
_	R	REACTION PIPE SIZE					
Ш		TYPE	4"	6"	8"	10"	12"
TEST PRESSURE	A B C D E	90° 180° 45° 22-1/2° 11-1/4°	0.89 0.65 0.48 0.25 0.13	2.19 1.55 1.19 0.60 0.30	3.82 2.78 2.12 1.06 0.54	11.14 8.38 6.02 3.08 1.54	17.2- 12.00 9.32 4.74 2.38

<u>NOTES</u>

- 1. POUR THRUST BLOCKS AGAINST UNDISTURBED MATERIAL. WHERE TRENCH WALL HAS BEEN DISTURBED, EXCAVATE LOOSE MATERIAL AND EXTEND THRUST BLOCK TO UNDISTURBED MATERIAL.
- 2. NO JOINTS SHALL BE COVERED WITH CONCRETE. POLYETHYLENE (6 MIL) SHALL BE PLACED AROUND FITTINGS PRIOR TO CONCRETE PLACEMENT.
- 3. ON BENDS AND TEES, EXTEND THRUST BLOCKS FULL LENGTH OF FITTING.
- 4. PLACE BOARD IN FRONT OF ALL PLUGS BEFORE POURING THRUST BLOCKS. WHERE M.J. PIPE IS USED, M.J. PLUG WITH RETAINER GLAND MAY BE SUBSTITUTED FOR END BLOCKINGS.


THRUST BLOCKING NOT TO SCALE




<u>NOTES</u>

- 1. HYDRANT INSTALLATION AND OPERATION TO CONFORM TO REGULATIONS OF THE TOWN OF
- 2. HYDRANT TO BE PAINTED YELLOW WITH A WHITE BONNET OR AS SPECIFIED BY THE MUNICIPALITY.
- 3. FIRE HYDRANT CONNECTION SHALL USE MEGALUG (RODS NOT ALLOWED).
- 4. DRAIN PLUG SHALL BE PLUGGED.
- 5. GATE VALVES SHALL BE 6" M.J. RESILIENT SEAT GATE VALVE, OPEN LEFT, CONFORMING TO DURHAM DPW REQUIREMENTS.

FIRE HYDRANT NOT TO SCALE



Portsmouth, NH 03801 133 Court Street (603) 433-2335 www.altus-eng.com



NOT FOR CONSTRUCTION

REVIEW

SSUED FOR:

REVISIONS

ISSUE DATE:

OCTOBER 8, 2025

NO. DESCRIPTION) REVIEW EBS 06/23/ REVISED PER COMMENTS EBS 10/08/2

DRAWN BY: _____ APPROVED BY: ____ 5440-SITE.dwg DRAWING FILE: ____

24" x 36" - 1" = NTS $11" \times 17" - 1" = NTS$

OWNER:

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

<u>APPLICANT:</u>

RIVERWOODS DURHAM 14 STONE QUARRY DRIVE DURHAM, NH 03824

RIVERWOODS DURHAM PHASE II

TAX MAP 209 LOT 33 STONE QUARRY DRIVE & DOVER ROAD (NH 108) DURHAM, NH

TITLE:

DETAIL SHEET

SHEET NUMBER:

NH FISH AND GAME CONSERVATION MEASURES APPLICABLE TO THIS PROJECT

- 1. BLANDING'S TURTLE (STATE ENDANGERED) AND NEW ENGLAND COTTONTAIL (STATE ENDANGERED) OCCUR WITHIN THE VICINITY OF THE PROJECT AREA. SPOTTED TURTLE (STATE THREATENED) ALSO VERY LIKELY OCCUR IN THE VICINITY DUE TO OVERLAPPING HABITAT USE AND DISTRIBUTION. ALL OPERATORS AND PERSONNEL WORKING ON OR ENTERING THE SITE SHALL BE MADE AWARE OF THE POTENTIAL PRESENCE OF THESE SPECIES AND SHALL BE PROVIDED NHFG CONTACT INFORMATION. SEE SPECIES FLYERS THIS SHEET.
- 2. SEE THIS SHEET FOR RARE SPECIES INFORMATION (E.G. IDENTIFICATION, OBSERVATION AND REPORTING OF OBSERVATIONS, WHEN TO CONTACT NHFG IMMEDIATELY AND NHFG CONTACT INFORMATION) SHALL BE COMMUNICATED DURING MORNING TAILGATE MEETINGS PRIOR TO WORK COMMENCEMENT DURING THE CONSTRUCTION PHASE OF THE PROJECT.
- 3. TURTLES MAY BE ATTRACTED TO DISTURBED GROUND DURING THE NESTING SEASON (MAY 15TH JULY 15TH). TURTLE NESTS ARE PROTECTED BY NH LAWS. IF A NEST IS OBSERVED OR SUSPECTED, OPERATORS SHALL CONTACT JOSH MEGYESY AT NHFG IMMEDIATELY FOR FURTHER CONSULTATION. SEE SPECIES FLYERS THIS SHEET FOR NHFG CONTACT INFORMATION.
- a. TO MINIMIZE THE POTENTIAL FOR NESTING TO OCCUR WITHIN THE PROJECT SITE:
- i. MINIMIZE GROUND DISTURBANCE ACTIVITIES DURING THE ACTIVE NESTING SEASON. LIMIT CLEARING AREAS AND DISTURBING GROUND UNTIL READY TO START ACTIVE CONSTRUCTION FOR A PROJECT COMPONENT.
- ii. MINIMIZE ACCESS OR MAKE AREAS LESS ATTRACTIVE TO WILDLIFE FOR NESTING FOR DISTURBED GROUND AREAS DURING ACTIVE NESTING SEASON. SOIL/SANDY MOUNDS OR OPEN SANDY/GRAVELY AREAS WITHIN THE ACTIVE PROJECT SITE SHALL BE COVERED WITH TARPS OR OTHER CONSTRUCTION MATERIALS AT THE END OF THE WORK DAY (NOTE TURTLES CAN MOVE INTO A SITE OVERNIGHT TO NEST — BE OBSERVANT FOR OF TRACKS AND NESTING SIGNS).
- b. THE NEST OR SUSPECTED NEST SHALL BE MARKED (SURROUNDING ROPED OFF OR CONE BUFFER DEPLOYED) AND AVOIDED; THIS SHALL BE COMMUNICATED TO ALL PERSONNEL ONSITE.
- c. SITE ACTIVITIES SHALL NOT OCCUR IN THE AREA SURROUNDING THE NEST OR SUSPECTED NEST UNTIL FURTHER GUIDANCE IS PROVIDED BY
- 4. CATCH BASINS CB #2, CB #17 AND CB #23 SHALL HAVE GRATE OPENINGS NO LARGER THAN 5"x3/8". OUTLET CONTROL STRUCTURES SHALL
- 5. YARD DRAINS SHALL HAVE HAVE GRATE OPENINGS NO LARGER THAN 6.5"x3/8" AND SHALL NOT CONTAIN GREASE HOODS. SEE PLAN SHEET
- 6. CATCH BASINS CB #10-1 AND CB #10-2 SHALL NOT CONTAIN GREASE HOODS. SEE PLAN SHEET C-6.1.
- 7. OUTLET CONTROL STRUCTURES SHALL NOT BE PLACED ADJACENT TO THE SIDE SLOPES BUT RATHER AS FAR AWAY AS POSSIBLE TO DETER WILDLIFE FROM CRAWLING ONTO THEM AND FALLING THROUGH THE GRATE OPENINGS. THESE STRUCTURES SHALL BE A MINIMUM OF 12"-18" ABOVE GRADE AND BE SET BACK AT LEAST 3' FROM ADJACENT SLOPES. SEE PLAN SHEET C-14.
- 8. IF HYDROSEEDING IS DEEMED NECESSARY, THE MIX SHALL NOT CONTAIN MICROPLASTICS AND DYES SHALL BE WATER-SOLUBLE AND ECO-FRIENDLY. HYDROSEEDING SHALL NOT OCCUR WITHIN 75 FEET OF WETLANDS. SEE PLAN SHEET C-12.

NOT CONTAIN SUMPS AND SHALL HAVE GRATE OPENINGS NO LARGER THAN 2"x2". SEE PLAN SHEETS C-6.1, C-6.2 AND C-14.

- 9. AVOID OR MINIMIZE THE USE OF FERTILIZERS IN UPLAND AREAS OR TRANSITION ZONES. IF FERTILIZERS ARE NECESSARY, USE ORGANIC VERSUS SYNTHETIC FERTILIZER OPTIONS. SYNTHETIC OPTIONS SHOULD BE AVOIDED; HOWEVER, IF CHOSEN, THEY SHALL BE CONTROLLED-RELEASED/SLOW-RELEASED AND AT LOW STRENGTHS. SEE PLAN SHEET C-12.
- 10. RIP-RAP SHALL BE FILLED WITH FINER MATERIAL (I.E., NATIVE WETLAND MATERIAL, NATIVE WETLAND SEED MIX, OR GRAVEL IN BETWEEN RIP-RAP) TO CREATE A RELATIVELY SMOOTH SURFACE FOR WILDLIFE TO TRAVERSE. SEE PLAN SHEET C-13.
- 11. STAGING OF CONSTRUCTION EQUIPMENT/MATERIAL AND VEHICLE PARKING SHALL NOT OCCUR IN SHRUB COVER OR WETLANDS AND SHRUB COVER SHALL NOT BE REMOVED BEYOND THE LIMITS OF THE CONSTRUCTION AREA. SEE PLAN SHEET C-7.1.
- 12. A NATIVE SEED MIXTURE SHALL BE APPLIED TO ALL AREAS AFFECTED BY CONSTRUCTION. THE SEED MIXTURE SHALL NOT CONTAIN INVASIVE SPECIES SUCH AS CROWN VETCH, BIRD'S-FOOT TREFOIL, ALSIKE CLOVER, OR FLAT PEA. SEE PLAN SHEET C-12.
- 13. ALL MANUFACTURED EROSION AND SEDIMENT CONTROL PRODUCTS, WITH THE EXCEPTION OF TURF REINFORCEMENT MATS, UTILIZED FOR, BUT NOT LIMITED TO, SLOPE PROTECTION, RUNOFF DIVERSION, SLOPE INTERRUPTION, PERIMETER CONTROL, INLET PROTECTION, CHECK DAMS, AND SEDIMENT TRAPS SHALL NOT CONTAIN PLASTIC, OR MULTIFILAMENT OR MONOFILAMENT POLYPROPYLENE NETTING OR MESH WITH AN OPENING SIZE OF
- GREATER THAN 1/8 INCHES. SEE PLAN SHEET C-12. 14. ALL OBSERVATIONS OF THREATENED OR ENDANGERED SPECIES ON THE PROJECT SITE SHALL BE REPORTED IMMEDIATELY TO THE NHFG NONGAME AND ENDANGERED WILDLIFE ENVIRONMENTAL REVIEW PROGRAM BY PHONE AT 603-271-2461 AND BY EMAIL AT NHFGREVIEW@WILDLIFE.NH.GOV, WITH THE EMAIL SUBJECT LINE CONTAINING THE NHB DATACHECK TOOL RESULTS LETTER ASSIGNED NUMBER, THE PROJECT NAME, AND THE TERM
- WILDLIFE SPECIES OBSERVATION. a. PHOTOGRAPHS OF THE OBSERVED SPECIES AND NEARBY ELEMENTS OF HABITAT OR AREAS OF LAND DISTURBANCE SHALL BE PROVIDED TO NHFG IN DIGITAL FORMAT AT THE ABOVE EMAIL ADDRESS FOR VERIFICATION, AS FEASIBLE.
- 13. IN THE EVENT A THREATENED OR ENDANGERED SPECIES IS OBSERVED ON THE PROJECT SITE DURING THE TERM OF THE PERMIT, THE SPECIES SHALL NOT BE DISTURBED, HANDLED, OR HARMED IN ANY WAY PRIOR TO CONSULTATION WITH NHFG AND IMPLEMENTATION OF CORRECTIVE ACTIONS RECOMMENDED BY NHFG.
- a. SITE OPERATORS SHALL BE ALLOWED TO RELOCATE WILDLIFE ENCOUNTERED IF DISCOVERED WITHIN THE ACTIVE WORK ZONE IF IN DIRECT HARM FROM PROJECT ACTIVITIES.
- b. WILDLIFE SHALL BE RELOCATED IN CLOSE PROXIMITY TO THE CAPTURE LOCATION BUT OUTSIDE OF THE WORK ZONE AND IN THE DIRECTION THE INDIVIDUAL WAS HEADING.
- c. NHFG SHALL BE CONTACTED IMMEDIATELY IF THIS ACTION OCCURS.
- 14. NHFG, INCLUDING ITS EMPLOYEES AND AUTHORIZED AGENTS, SHALL HAVE ACCESS TO THE PROPERTY DURING THE TERM OF THE PERMIT.



NEW HAMPSHIRE STATE ENDANGERED

BLANDING'S TURTLE





Report Sightings: Contact Wildlife Biologist Josh Megyesy at (603) 271 – 1125 or the Wildlife Division at (603) 271 – 2461. Observation reports can be sent to RAARP@wildlife.nh.gov. Photographs and exact locations are strongly encouraged.

Specific Information:

- Adults are 7 9 inches long. Shell is highly domed with light speckles.
- Distinct yellow throat and chin. Uses variety of wetlands and moves
- extensively over land. Turtles are frequently concealed by leaves and undergrowth and may not be easily
- Turtles are most active from April 15 October 15.
- During nesting season (May 15 July 15) turtles are attracted to disturbed ground.



This species is protected under RSA 212-A and Fis 1000. Thank you for reporting any observations. PLEASE DO NOT DISTURB OR HANDLE WILDLIFE

FEATURES & SPECIFICATIONS

// LITHONIA LIGHTING*

INTENDED USE — Typical applications include corridors, lobbies, conference rooms and private offices.

CONSTRUCTION — Galvanized steel mounting/plaster frame; galvanized steel junction box with bottom-

NEW HAMPSHIRE STATE THREATENED

SPOTTED TURTLE



Report Sightings: Contact Wildlife Biologist Josh Megyesy at (603) 271 – 1125 or the Wildlife Division at (603) 271 – 2461. Observation reports can be sent to RAARP@wildlife.nh.gov. Photographs and exact locations are strongly encouraged.



Specific Information:


visible.

- Adults are 3 5 inches long
- Shell is black or brown, fairly flat, and with yellow spots.
- Uses variety of wetlands and moves extensively over land.
- Turtles are frequently concealed by leaves and undergrowth and may not be easily
- Turtles are most active from April 15 October 15.
- During nesting season (May 15 July 15) turtles are attracted to disturbed ground.







This species is protected under RSA 212-A and Fis 1000. Thank you for reporting any observations. PLEASE DO NOT DISTURB OR HANDLE WILDLIFE



LIGHT FIXTURE CUT SHEETS







RADPT LED						
Series	Performance pack	age	Color temperature	Distribution	Voltage	Mounting (required)
RADPT LED	P1 3,000 Lumens P2 5,000 Lumens P3 7,000 Lumens P4 10,000 Lumen P5 15,000 Lumen	S	27K 2700K 30K 3000K 35K 3500K 40K 4000K 50K 5000K	SYM Symmetric type V ASY Asymmetric type IV PATH Pathway Type III	MVOLT ² 277 ² 120 ² 347 208 ² 480 240 ²	PT43 Slips inside a 4"OD round metal pole RADPT20 Slips over a 2 3/8"diameter tenon (4" tall tenon required) RADPT25 Slips over a 2 7/8"diameter tenon (4" tall tenon required)
Control options		Other	options		Finish (required)	
PE Butto FAO Field DMG 0-10v puller use w	led It AIR 2.0 enabled ⁴ In photocell ⁴ adjustable output ⁴ If dimming wires d outside fixture (for with an external con- ordered separately) ⁵	SF DF R90	Single Fuse ² Double Fuse ² Rotated optics ⁶	Shipped installed HS Houseside shield ⁷	DDBXD Darkbronze DBLXD Black DNAXD Natural aluminum DWHXD White	DDBTXD Textured dark bronze DBLBXD Textured black DNATXD Textured natural aluminum DWHGXD Textured white

LITHONIA COMMERCIAL OUTDOOR One Lithonia Way • Conyers, Georgia 30012 • Phone: 1-800-705-SERV (7378) • www.lithonia.com © 2011-2024 Acuity Brands Lighting, Inc. All rights reserved Rev. 11/14/24

DETAIL SHEET

SHEET NUMBER:

C-22

COMMERCIAL OUTDOOR

NOT TO SCALE

Portsmouth, NH 03801

www.altus-eng.com

NOT FOR CONSTRUCTION

REVIEW

JULY 23, 2025

5440-SITE.dwa

24" x 36" - 1" = NTS

 $11" \times 17" - 1" = NTS$

RIVERWOODS DURHAM

14 STONE QUARRY DRIVE

DURHAM, NH 03824

RIVERWOODS DURHAM

14 STONE QUARRY DRIVE

DURHAM, NH 03824

RIVERWOODS

DURHAM PHASE II

TAX MAP 209 LOT 33

STONE QUARRY DRIVE

& DOVER ROAD (NH 108) DURHAM, NH

BY DATE

EBS 06/23/2

SSUED FOR:

ISSUE DATE:

REVISIONS

O REVIEW

DRAWN BY:

OWNER:

<u>APPLICANT:</u>


APPROVED BY: ___

DRAWING FILE: ___

NO. DESCRIPTION

133 Court Street

(603) 433-2335



5. It is the contractor's responsibility to verify drawings provided are to the correct scale prior to any bid, estimate or installation. A graphic scale bar has been provided on each sheet for this purpose. If it is determined that the scale of the drawing is

incorrect, the landscape architect will provide a set of drawings at the correct scale, at the request of the contractor. 6. Trees to Remain within the construction zone shall be protected from damage for the duration of the project by snow fence or other suitable means of protection to be approved by Landscape Architect or Client's Representative. Snow fence shall be located at the drip line at a minimum and shall include any and all surface roots. Do not fill or mulch on the trunk flare. Do not disturb roots. In order to protect the integrity of the roots, branches, trunk and bark of the tree(s) no vehicles or construction equipment shall drive or park in or on the area within the drip line(s) of the tree(s). Do not store any refuse or construction materials or portalets within the tree protection area. This plan is for review purposes only, NOT for Construction. Construction Documents will be provided upon request.

8. Location, support, protection, and restoration of all existing utilities and appurtenances shall be the responsibility of the

9. The Contractor shall verify exact location and elevation of all utilities with the respective utility owners prior to construction. Call DIGSAFE at 1-888-344-7233.

10. The Contractor shall procure any required permits prior to construction.

11. Prior to any landscape construction activities Contractor shall test all existing loam and loam from off-site intended to be used for lawns and plant beds using a thorough sampling throughout the supply. Soil testing shall indicate levels of pH, nitrates. macro and micro nutrients, texture, soluble salts, and organic matter. Contractor shall provide Landscape Architect with test results and recommendations from the testing facility along with soil amendment plans as necessary for the proposed plantings to thrive. All loam to be used on site shall be amended as approved by the Landscape Architect prior to placement. 12. Contractor shall notify landscape architect or owner's representative immediately if at any point during demolition or

construction a site condition is discovered which may negatively impact the completed project. This includes, but is not limited to, unforeseen drainage problems, unknown subsurface conditions, and discrepancies between the plan and the site. If a contractor is aware of a potential issue, and does not bring it to the attention of the landscape architect or owner's representative immediately, they may be responsible for the labor and materials associated with correcting the problem. 13. The Contractor shall furnish and plant all plants shown on the drawings and listed thereon. All plants shall be nursery-grown under climatic conditions similar to those in the locality of the project. Plants shall conform to the botanical names and

standards of size, culture, and quality for the highest grades and standards as adopted by the American Association of

Nurserymen, Inc. in the American Standard of Nursery Stock, American Standards Institute, Inc. 230 Southern Building, 14. A complete list of plants, including a schedule of sizes, quantities, and other requirements is shown on the drawings. In the event that quantity discrepancies or material omissions occur in the plant materials list, the planting plans shall govern.

15. All plants shall be legibly tagged with proper botanical name. 16. The Contractor shall guarantee all plants for 2 years from time of acceptance. 17. Owner or Owner's Representative will inspect plants upon delivery for conformity to Specification requirements. Such approval shall not affect the right of inspection and rejection during or after the progress of the work. The Owner reserves the right to inspect and/or select all trees at the place of growth and reserves the right to approve a representative sample of each type of shrub, herbaceous perennial, annual, and ground cover at the place of growth. Such sample will serve as a minimum standard

for all plants of the same species used in this work. 18. No substitutions of plants may be made without prior approval of the Owner or the Owner's Representative for any reason.

19. All landscaping shall be provided with the following: a. Outside hose attachments spaced a maximum of 150 feet apart, and

b. An underground automatic irrigation system utilizing the latest technology in water conservation 20. If an automatic irrigation system is installed, all irrigation valve boxes shall be located within planting bed areas. 21. The contractor is responsible for all plant material from the time their work commences until final acceptance. This includes but is not limited to maintaining all plants in good condition, the security of the plant material once delivered to the site, and watering of plants. Plants shall be appropriately watered prior to, during and after planting. It is the contractor's responsibility to provide clean water suitable for plant health from off site, should it not be available on site.

22. All disturbed areas will be dressed with 6" of topsoil and planted as noted on the plans or seeded except plant beds. Plant beds shall be prepared to a depth of 12" with 75% loam and 25% compost. 23. Trees, ground cover, and shrub beds shall be mulched to a depth of 2" with one-year-old, well-composted, shredded native bark not longer than 4" in length and 1/2" in width, free of woodchips and sawdust. Mulch for ferns and herbaceous perennials shall be no longer than 1" in length. Trees in lawn areas shall be mulched in a 5' diameter min. saucer. Color of mulch shall be

24. Drip strip shall extend to 6" beyond roof overhang and shall be edged with 3/16" thick metal edger. 25. In no case shall mulch touch the stem of a plant nor shall mulch ever be more than 3" thick total (including previously applied mulch) over the root ball of any plant. 26. Secondary lateral branches of deciduous trees overhanging vehicular and pedestrian travel ways shall be pruned up to a

height of 6' to allow clear and safe passage of vehicles and pedestrians under tree canopy. Within the sight distance triangles at vehicle intersections the canopies shall be raised to 8' min. 27. Snow shall be stored a minimum of 5' from shrubs and trunks of trees.

28. Landscape Architect is not responsible for the means and methods of the contractor.

interior twigs and lateral branches may be pruned; however, Do NOT remove the terminal buds of branches that extend to the edge of the crown

Trees less than 3" in caliper shall be staked with three stakes per tree, spaced evenly around the trunk with 12 gauge wire. Plastic hose sections shall be used at attachment to trees. Each wire shall be flagged with a visual marker. 5' long min. wooden stakes shall be used to anchor the wires. Stakes shall be driven at least 12" outside the edge of the planting pit into stable soil. Remove all staking NO LATER than the end of the first growing season after planting.

> Mark the north side of the tree in the nursery. Rotate the tree to face north at the site whenever possible.

4 in. high earth saucer beyond edge of root

2 IN. max. Mulch. Do NOT place mulch in contact with tree trunk. Maintain the mulch weed-free for a minimum of three years

Tamp soil around root ball base firmly with foot pressure so that root ball does not

after planting.

Place root ball on unexcavated or tamped

Tree Planting Detail

2 times the diameter of the root ball - Permeable area in which tree is to be planted shall be no less than a 3' wide radius from the base of

Mulch Ring

5'-0" diameter, min.

(8FT.) diam.

preferred

1'-0"

Remove all twine, rope, wire, and burlap If plant is shipped with a wire basket around the root ball,

Backfill with existing soil, in sandy and heavy clay soils

add 20% max. by volume composted organic material to

a visual marker. 24" stakes or metal drive anchors shall

be used to anchor the guy wires. Stakes/Anchors shall

into stable soil. Remove all guying NO LATER than the

Each tree must be planted such that the original trunk flare

original trunk flare is not visible may be rejected. Do NOT

Before planting Contractor shall inspect the rootball for the

location of the original root flare. If the original root flare is

not visible at the top of the root ball then the Contractor

the original root flare. All secondary and girdling roots

shall be removed prior to planting. Trees with 4" or more

of extraneous soil and/or adventitious roots greater than

1/8" shall be rejected. The tree shall be planted with the

original root flare at or slightly (2-3") above surrounding

shall then gently remove from the top of the root ball any

excess soil from nursery operations that may be covering

is visible at the top of the root ball. Trees where the

be driven 12" min. outside the edge of the planting pit

end of the first growing season after planting.

6" Corrugated PVC tree sock


cover the top of the root ball with soil.

finished grade.

the existing soil.

prior to planting, the contractor shall cut away the bottom of the wire basket, leaving the sides in place. Once the tree is placed and faced, the contractor shall remove the remainder of the wire basket and backfill the planting pit as noted above.

VMDrawn By: Checked By: RW Scale: 1'' = 20' - 0''October 7, 2025 Date: Revisions:



© 2025 Woodburn & Company Landscape Architecture, LLC



iverWoods Durham Phase II

LANDSCAPE PLAN

Sheet 2 of 2

VM

RW

1'' = 20' - 0''

October 7, 2025

© 2025 Woodburn & Company Landscape Architecture, LLC

Drawn By:

Checked By:

Scale:

Date:

Revisions:







1/8" EXTERIOR ELEVATIONS - HYBRID HOME 'A'

RIVERWOODS DURHAM PHASE 2 | DESIGN DEVELOPMENT

A500 ARCHITECTURE

Durham, New Hampshire PRELIMINARY DRAFT - NOT FOR CONSTRUCTION

EXTERIOR ELEVATION KEY NOTES:

822 288

322 248

FP2

FP2

222 222

111 111

STANDING SEAM GALVALUME METAL ROOF THREE DIMENSIONAL ASPHALT SHINGLES

STONE VENEER

MANUFACTURED STONE FIBER CEMENT SIDING WITH 5" LAP - COLOR B


FIBER CEMENT SIDING WITH 5" LAP - COLOR C FIBER CEMENT PANEL - COLOR A

FIBER CEMENT PANEL - COLOR B

FIBER CEMENT VERTICAL BATTEN SIDING - COLOR A (1X3 FIBER CEMENT BATTENS @ 16" O.C.)

FIBER CEMENT VERTICAL BATTEN SIDING - COLOR A


(1X3 FIBER CEMENT BATTENS @ 8" O.C.)



142'-4 7/8" FOURTH FLOOR 133'-3 3/4"

THIRD FLOOR

FIRST FLOOR 100'-0"





RIVERWOODS DURHAM PHASE 2 | DESIGN DEVELOPMENT

285 285

A501


FV2

1/8" EXTERIOR ELEVATIONS - HYBRID HOME 'B'

A501 ARCHITECTURE

EXTERIOR ELEVATION KEY NOTES:

- MR STANDING SEAM GALVALUME METAL ROOF A THREE DIMENSIONAL ASPHALT SHINGLES
- STONE VENEER
- MS MANUFACTURED STONE
- F5 FIBER CEMENT SIDING WITH 5" LAP COLOR B F52 FIBER CEMENT SIDING WITH 5" LAP - COLOR C
- P FIBER CEMENT PANEL COLOR A
- FIBER CEMENT PANEL COLOR B
- FIBER CEMENT VERTICAL BATTEN SIDING COLOR A (1X3 FIBER CEMENT BATTENS @ 16" O.C.)
- 2 FIBER CEMENT VERTICAL BATTEN SIDING COLOR A
- (1X3 FIBER CEMENT BATTENS @ 8" O.C.)
- FIBER CEMENT VERTICAL BATTEN SIDING COLOR D (1X3 FIBER CEMENT BATTENS @ 16" O.C.)











1/8" EXTERIOR ELEVATIONS - CLUBHOUSE

BER 2025
A502 ARCHITECTURE









RiverWoods Durham Phase 2 | Concept Design

MAINTENANCE GARAGE

5 JUNE 2025
A503 ARCHITECTURE